



Dwight E. Nunn
Vice President

June 14, 2002

U. S. Nuclear Regulatory Commission
Document Control Desk
Washington, DC 20555

Subject: **Docket No. 50-361**
Special Report: Inservice Inspection of Steam Generator Tubes, Cycle 12
San Onofre Nuclear Generating Station, Unit 2

Gentlemen:

On June 2, 2002, Southern California Edison (SCE) completed the inservice inspection of steam generator tubes at San Onofre Nuclear Generating Station Unit 2. Technical Specification (TS) 5.7.2.c requires SCE to:

- Report the number of tubes plugged and tubes sleeved in each steam generator within 15 days of completing the inspection.
- Report the results of the steam generator tube inspections which fall into Category C-3 prior to resumption of plant operation. This report is required to include a description of the investigations conducted to determine the cause of the tube degradation and corrective measures taken to prevent recurrence.
- Report the complete results of steam generator tube inspections within 12 months of inspection completion.

The attachment to this letter, "Special Report – Inservice Inspection of Steam Generator Tubes," satisfies these requirements. This report also follows the guidance contained in NEI 97-06, Rev. 1, "Steam Generator Program Guidelines," dated January 2001 and contains no new commitments.

If you require any additional information, please advise.

Sincerely,

A handwritten signature in black ink, appearing to read 'Dwight E. Nunn', is written over a horizontal line.

Attachments:

cc: E. W. Merschoff, Regional Administrator, NRC Region IV
A. B. Wang, NRC Project Manager, San Onofre Units 2 & 3
C. C. Osterholtz, NRC Senior Resident Inspector, San Onofre Units 2 & 3
Institute of Nuclear Power Operations (INPO)

P. O. Box 128
San Clemente, CA 92674-0128
949-368-1480
Fax 949-368-1490

AD47

SPECIAL REPORT - INSERVICE INSPECTION OF STEAM GENERATOR TUBES

Regulatory Reporting Requirements

Reporting Requirement 5.7.2.c of Appendix A, Technical Specification to Facility Operating License NPF-10, requires the number of tubes plugged and tubes sleeved in each steam generator to be reported the Nuclear Regulatory Commission within 15 days following completion of the inspection.

Reporting Requirement 5.7.2.c of Appendix A, Technical Specification to Facility Operating License NPF-10, requires the results of steam generator tube inspections which fall into Category C-3 to be reported the Nuclear Regulatory Commission prior to resumption of plant operation.

Reporting Requirement 5.7.2.c of Appendix A, Technical Specification to Facility Operating License NPF-10, requires the complete results of steam generator tube inspections to be reported the Nuclear Regulatory Commission within 12 months following completion of the inspection.

Planned Inspection Scope

Table 1 summarizes the planned inspection program. Also, when indications by the bobbin probe were non-quantifiable or distorted, the inspection program included inspection with the Plus-Point Probe. Table 2 provides the list of Nondestructive Examination (NDE) techniques utilized for each degradation mechanism.

There were no significant inspection program scope expansions in response to inspection results.

Results

This report satisfies the listed regulatory reporting requirements.

The contents of this report were prepared using the guidance contained in NEI 97-06, Rev. 1, "Steam Generator Program Guidelines." The NEI guidance is an initiative to unify the industry approach towards steam generator issues and strengthen, where necessary, the steam generator program.

Table 3 summarizes the number of tubes repaired and active degradation mechanisms found. Each tube is only counted once in this listing, although it may also have an eddy current indication of a type below the point in the listing where it appears. The Appendices provide the complete results of the steam generator tubing inservice inspection.

Table 4 summarizes in-situ pressure and leak testing results. This particular testing demonstrated the structural and leakage (i.e., there was no leakage) integrity of the tested tubes consistent with EPRI guidelines. Eddy current testing results and in-situ pressure and leak testing results (Condition Monitoring) provide assurance that performance criteria in the NEI guidance (structural integrity and accident-induced leakage) were met during operation prior to this inspection.

Repair of Tubes

Table 5 provides an itemized listing of the tubes plugged in steam generator E-088 along with the corresponding Table 3 category specifying the indication orientation/location.

Table 6 provides an itemized listing of the tubes sleeved in steam generator E-088 along with the corresponding Table 3 category specifying the indication orientation/location.

Table 7 provides an itemized listing of tubes plugged in steam generator E-089 along with the corresponding Table 3 category specifying the indication orientation/location.

Table 8 provides an itemized listing of the tubes sleeved in steam generator E-089 along with the corresponding Table 3 category specifying the indication orientation/location.

Repair Methods, Number of Tubes Repaired and Effective Plugging Percentage

All tube plugging was performed using the design, materials, and installation methods of FRAMATOME ANP (FANP). A "roll" method was used for all tube plugs. One tube was "stabilized" in the vicinity of the top of the tubesheet using the design, materials, and installation methods of FANP.

All tube sleeving was performed using the welded sleeve design, materials, and installation methods of Westinghouse (formerly ABB Combustion Engineering). This repair method is specifically addressed in Technical Specification 5.5.2.11.f.1.j for Unit 2.

Forty-nine tubes were plugged, and seventy-five tubes were sleeved in Steam Generator E-088 during the Cycle 12 refueling outage. A total of 773 tubes have been plugged, and to date, 255 sleeved tubes are in service. The design number of tubes is 9350 tubes and the sleeve to plug equivalency ratio is thirty-eight sleeves per plug. The effective plugging percentage for E-088 is 8.4%.

Fifty-two tubes were plugged, and forty-three tubes were sleeved in Steam Generator E-089 during the Cycle 12 refueling outage. A total of 817 tubes have been plugged, and to date, 146 sleeved tubes are in service. The design number of tubes is 9350 tubes and the sleeve to plug equivalency ratio is thirty-eight sleeves per plug. The effective plugging percentage for E-089 is 8.8%.

Causes and Corrective Actions

The degradation detected during this inspection remained within the Technical Specification category C-3. There is no significant update from previous reports of causes and corrective actions for Category C-3 results. Thus, this portion of a previous report is provided below.

Actions have been taken to improve the secondary side chemistry environment for steam generator tubing in both Unit 2 steam generators. These actions have been reviewed by a panel of industry experts for application at SONGS. The expert panel concurs with these measures. The actions include:

1. Chemical cleaning of the entire tube bundle (full bundle) performed during the Cycle 9 refueling outage in December 1996.
2. Addition of an inhibitor (titanium dioxide) for IGA/SCC immediately after the chemical cleaning for maximum crevice penetration potential. This is ongoing.
3. Use of Ethanolamine (ETA) for pH control of the secondary fluids. This is ongoing.
4. Boric acid addition in the secondary side to help reduce denting of the tube supports and stress corrosion cracking of tubing. This is ongoing.

In addition, SCE reduced the reactor coolant temperature at the steam generator inlet (T-hot) by about 13°F. SCE expects this will reduce stress corrosion cracking of the tubing initiating from the inside diameter of the tubing. The first phase of this change, a reduction of about 4°F, was completed in January 1998. The final phase of this change, a reduction of an additional 9°F, was completed in February 1999.

Description of Tables and Appendices

- Table 1 - Summary of the Planned Inspection Program for the Unit 2 Cycle 12 (U2C12) Refueling Outage
- Table 2 - List of Nondestructive Examination (NDE) Techniques Utilized for Each Degradation Mechanism for the U2C12 Refueling Outage
- Table 3 - Number of Tubes Repaired and Active Degradation Mechanisms Found During the U2C12 Refueling Outage
- Table 4 - Summary of Results of In-Situ Pressure and Leak Testing for the U2C12 Refueling Outage
- Table 5 - U2C12 Refueling Outage Tubes Plugged, Steam Generator E-088
- Table 6 - U2C12 Refueling Outage Tubes Sleeved, Steam Generator E-088
- Table 7 - U2C12 Refueling Outage Tubes Plugged, Steam Generator E-089
- Table 8 - U2C12 Refueling Outage Tubes Sleeved, Steam Generator E-089
- Appendix 1 - Steam Generator Reference Information
- Appendix 2 - Legend for Appendices 3 and 4
- Appendix 3 - Inspection Summary, Steam Generator E-088
- Appendix 4 - Inspection Summary, Steam Generator E-089

**Table 1 - Summary of the Planned Inspection Program for the
Unit 2 Cycle 12 (U2C12) Refueling Outage**

	Number of Tubes/Percentage of Tubes	
	Steam Generator E-088	E-089
Full length of tube with the bobbin probe (excluding sleeved regions and U-bends for Rows 1-3)	8626 / 100%	8585 / 100%
Hot leg expansion transition at the top-of-tubesheet with the Plus-Point Probe	8446 / 100%	8482 / 100%
Cold leg expansion transition at the top-of-tubesheet with the Plus-Point Probe	2680 / 31%	2646 / 30%
U-bend regions of Rows 1, 2, and 3 with both mid and high frequency Plus-Point Probes	181 / 100%	179 / 100%
Plus-Point Probe examinations of tube support intersections with dents greater than, or equal to, 2 volts	3293 / 100%	2097 / 100%
Plus-Point Probe examination of hot leg dings greater than, or equal to, 5 volts	118 / 100%	52 / 100%
Plus-Point Probe examination of all tube support intersections with quantified wear indications by the bobbin probe	362 / 100%	352 / 100%
Full length of sleeves with the Plus-Point Probe	180 / 100%	103 / 100%

Table 2 – List of Nondestructive Examination (NDE) Techniques Utilized for Each Degradation Mechanism for the U2C12 Refueling Outage

Indication Orientation/Location	Detection	Probe Type for Characterization
Axially oriented ID (initiated on the inside-diameter of the tubing wall) indications at tube support locations	Bobbin Plus Point (Note 1)	Plus Point Plus Point
Axially oriented OD (initiated on the outside-diameter of the tubing wall) indications at tube support locations	Bobbin Plus Point (Note 1)	Plus Point Plus Point
Axially oriented OD indications not associated with a tube support (freespan)	Bobbin	Plus Point
Circumferentially oriented ID indications near or below the expansion transition at the top of the hot leg tubesheet	Plus Point	Plus Point
Circumferentially oriented OD indications near the expansion transition at the top of the hot leg tubesheet	Plus Point	Plus Point
Axially oriented indications in the sludge pile region near the top of the hot leg tubesheet	Plus Point	Plus Point
Axially oriented ID indications near or below the expansion transition at the top of the hot leg tubesheet	Plus Point	Plus Point
Indications of wear at tube support locations	Bobbin	Plus Point

Note 1: Plus-Point technique is used at dents with greater than, or equal to, two volts.

**TABLE 3 – Number of Tubes Repaired and Active Degradation Mechanisms Found
During the U2C12 Refueling Outage**

Category	Indication Orientation/Location	Steam Generator	
		E-088	E-089
1	Tubes with axially oriented ID (initiated on the inside-diameter of the tubing wall) indications at tube support locations. (ID Axial @ Support)	4	2
2	Tubes with axially oriented OD (initiated on the outside-diameter of the tubing wall) indications at tube support locations. (OD Axial @ Support)	19	10
3	Tubes with axially oriented OD indications not associated with a tube support (freespan). (OD Axial @ Freespan)	6	8
4	Tubes with circumferentially oriented ID indications near the expansion transition at the top of the hot leg tubesheet. (ID Circ @ TSH)	30	12
5	Tubes with circumferentially oriented OD indications near the expansion transition at the top of the hot leg tubesheet. (OD Circ @ TSH)	8	17
6	Tubes with axially oriented OD indications in the sludge pile region near the top of the hot leg tubesheet. (OD Axial @ Sludge Pile TSH)	6	8
7	Tubes with axially oriented OD indications near the expansion transition at the top of the hot leg tubesheet. (OD Axial @ TSH)	0	0
8	Tubes with axially oriented ID indications near the expansion transition at the top of the hot leg tubesheet. (ID Axial @ TSH)	2	0
9	Tubes with axially oriented ID indications below the inlet top-of-tubesheet. (ID Axial below TSH)	26	9
10	Tubes with circumferentially oriented ID indications below the inlet top-of-tubesheet. (ID Circ below TSH)	9	1
11	Tubes with indications of wear at tube support locations. (Wear @ Support)	14	23
12	Tubes with volumetric indications. (OD Vol @ Miscellaneous)	0	2
13	Miscellaneous preventative plugging (not an active degradation mechanism). (Prevent @ Miscellaneous)	0	3
Total		124	95

TABLE 4

**SONGS-2 IN SITU PRESSURE TEST LIST
S/G 88 MAY-2002**

REGION	TUBE AND EDDY CURRENT INFORMATION							IN-SITU TEST RESULTS			
	TUBE INFORMATION			PLUS POINT DATA				GPM @ NOPD	GPM @ MSLB	GPM @ NOPD POST MSLB	PRESURE 3xNOPD
	ROW	COL	LOCATION	LENGTH	VOLTS	Max. Depth %	PDA or Avg. Depth %	ORIENTATION			
EGGCRATE	27	115	05H + 0.01	0.65	0.31	93%	34%	OD AXIAL	0	0	0
											5000

**SONGS-2 IN SITU PRESSURE TEST LIST
S/G 89 MAY-2002**

REGION	TUBE AND EDDY CURRENT INFORMATION							IN-SITU TEST RESULTS			
	TUBE INFORMATION			PLUS POINT DATA				GPM @ NOPD	GPM @ MSLB	GPM @ NOPD POST MSLB	PRESURE 3xNOPD
	ROW	COL	LOCATION	LENGTH	VOLTS	Max. Depth %	PDA or Avg. Depth %	ORIENTATION			
EGGCRATE	13	119	06H - 0.18	0.18	0.24	71%	N/A	OD AXIAL	0	0	0
LOW ROW U-BEND	1	165	DBH + 9.91	N/A	N/A	N/A	N/A	DATA QUALITY	0	0	0
											5000

NOTES:

GPM = Gallons per Minute

NOPD = Normal Operation Pressure Differential

MSLB = Main Steam Line Break Pressure Differential

N/A = Not Applicable

OD = Degradation initiated on the outside diameter of the tubing

ID = Degradation initiated on the inside diameter of the tubing

PDA = Percent degraded area

**TABLE 5 – SONGS U2C12 Refueling Outage Tubes Plugged
STEAM GENERATOR E-088**

Row	Column	Reason for Plugging Tube (per Table 3)
4	12	OD Axial @ Sludge Pile TSH
15	13	OD Axial @ Support
37	13	OD Axial @ Freespan
80	24	OD Axial @ Support
84	24	OD Axial @ Support
78	26	OD Axial @ Support
85	27	OD Axial @ Support
88	30	OD Axial @ Support
90	40	OD Axial @ Support
21	49	ID Axial @ Support
18	58	OD Axial @ Support
13	61	OD Axial @ Support
33	69	OD Axial @ Support
145	73	Wear @ Support
46	74	Wear @ Support
46	78	Wear @ Support
51	79	Wear @ Support
53	81	Wear @ Support
55	85	ID Axial below TSH
147	85	Wear @ Support
56	86	Wear @ Support
143	87	OD Axial @ Support
56	88	ID Axial below TSH
147	89	Wear @ Support
54	90	Wear @ Support
56	90	Wear @ Support
145	91	Wear @ Support
47	99	Wear @ Support
44	100	Wear @ Support
39	101	Wear @ Support
54	108	OD Axial @ Freespan
31	109	ID Axial @ Support

**TABLE 5 (CONT.) – SONGS U2C12 Refueling Outage Tubes Plugged
STEAM GENERATOR E-088**

Row	Column	Reason for Plugging Tube (per Table 3)
133	109	OD Axial @ Freespan
28	112	OD Axial @ Support
27	115	OD Axial @ Support
29	115	OD Axial @ Support
22	116	ID Axial @ Support
18	118	ID Axial @ Support
37	119	ID Axial below TSH
10	120	ID Circ below TSH
18	124	OD Axial @ Freespan
87	133	OD Axial @ Support
105	133	OD Axial @ Support
21	159	OD Axial @ Support
4	162	ID Axial below TSH
32	164	OD Axial @ Support
22	166	OD Axial @ Freespan
22	168	OD Axial @ Freespan
24	170	OD Axial @ Support

**TABLE 6 – SONGS U2C12 Refueling Outage Tubes Sleeved
STEAM GENERATOR E-088**

Row	Column	Reason for Sleeving Tube (per Table 3)
17	27	ID Axial below TSH
17	35	ID Circ @TSH
8	36	ID Circ below TSH
18	36	ID Circ @ TSH
19	39	ID Circ @ TSH
16	44	ID Circ @ TSH
6	46	ID Circ below TSH
24	48	ID Circ below TSH
25	49	ID Circ @ TSH
45	55	OD Circ @ TSH
48	58	ID Circ below TSH
90	58	ID Circ @ TSH
17	61	ID Axial below TSH
12	62	ID Circ below TSH
62	62	ID Circ @ TSH
54	64	ID Axial below TSH
49	65	OD Axial @ Sludge Pile TSH
30	68	ID Axial @ TSH
36	68	ID Circ below TSH
37	69	ID Axial below TSH
65	69	ID Circ @ TSH
30	70	ID Axial @ TSH
68	70	ID Circ @ TSH
49	71	ID Axial below TSH
46	72	ID Axial below TSH
62	72	ID Circ @ TSH
82	72	ID Circ @ TSH
54	74	ID Axial below TSH
68	74	ID Circ @ TSH
44	76	ID Axial below TSH
67	83	OD Axial @ Sludge Pile TSH
86	86	OD Circ @ TSH

**TABLE 6 (CONT.) – SONGS U2C12 Refueling Outage Tubes Sleeved
STEAM GENERATOR E-088**

Row	Column	Reason for Sleeving Tube (per Table 3)
58	88	ID Axial below TSH
82	88	ID Circ @ TSH
71	89	OD Axial @ Sludge Pile TSH
68	90	OD Axial @ Sludge Pile TSH
56	92	ID Axial below TSH
77	93	OD Circ @ TSH
77	97	OD Circ @ TSH
81	97	ID Circ @ TSH
97	97	ID Circ @ TSH
64	98	OD Axial @ Sludge Pile TSH
74	100	OD Circ @ TSH
68	102	ID Circ @ TSH
41	103	ID Axial below TSH
61	103	ID Circ @ TSH
79	103	ID Circ @ TSH
52	104	ID Axial below TSH
51	105	ID Axial below TSH
36	106	ID Axial below TSH
72	106	ID Circ @ TSH
36	108	ID Axial below TSH
114	108	OD Circ @ TSH
49	109	ID Axial below TSH
67	109	OD Circ @ TSH
51	111	ID Axial below TSH
57	111	ID Axial below TSH
83	111	ID Circ @ TSH
22	112	ID Axial below TSH
23	113	ID Axial below TSH
65	113	ID Circ @ TSH
28	114	ID Axial below TSH
46	116	ID Circ @ TSH
55	117	OD Circ @ TSH
25	119	ID Circ below TSH

**TABLE 6 (CONT.) – SONGS U2C12 Refueling Outage Tubes Sleeved
STEAM GENERATOR E-088**

Row	Column	Reason for Sleeving Tube (per Table 3)
65	119	ID Circ @ TSH
27	121	ID Circ @ TSH
39	121	ID Circ @ TSH
65	121	ID Circ @ TSH
34	122	ID Axial below TSH
47	123	ID Circ @ TSH
18	126	ID Circ @ TSH
58	134	ID Circ @ TSH
15	135	ID Circ below TSH
12	138	ID Circ @ TSH

**TABLE 7 – SONGS U2C12 Refueling Outage Tubes Plugged
STEAM GENERATOR E-089**

Row	Column	Reason for Plugging Tube (per Table 3)
18	16	OD Axial @ Support
93	23	Wear @ Support
67	31	OD Axial @ Support
9	33	ID Axial @ Support
95	33	OD Axial @ Support
93	35	OD Axial @ Freespan
110	36	OD Axial @ Freespan
102	38	OD Axial @ Support
106	40	OD Axial @ Freespan
114	46	OD Axial @ Support
38	52	OD Axial @ Freespan
34	54	ID Axial @ Support
121	77	OD Axial @ Support
65	79	OD Axial @ Sludge Pile TSH
55	81	Wear @ Support
147	81	Wear @ Support
54	82	Wear @ Support
55	83	Wear @ Support
75	85	Wear @ Support
61	87	OD Circ @ TSH
56	88	Wear @ Support
58	88	Wear @ Support
56	90	Wear @ Support
62	90	OD Circ @ TSH
145	91	Wear @ Support
52	92	Wear @ Support
54	92	Wear @ Support
55	95	Wear @ Support
71	97	Wear @ Support
48	98	Wear @ Support
50	98	Wear @ Support
45	99	Wear @ Support
51	99	Wear @ Support
38	102	Wear @ Support
35	105	ID Axial below TSH

TABLE 7 (CONT.) – SONGS U2C12 Refueling Outage Tubes Plugged
STEAM GENERATOR E-089

Row	Column	Reason for Plugging Tube (per Table 3)
73	105	Wear @ Support
44	108	Wear @ Support
68	112	OD Axial @ Freespan
13	119	OD Axial @ Support
4	120	OD Axial @ Support
19	121	OD Axial @ Support
79	121	Wear @ Support
22	126	OD Axial @ Freespan
120	128	OD Axial @ Freespan
2	154	OD Vol @ Miscellaneous
2	158	OD Vol @ Miscellaneous
74	160	Wear @ Support
38	164	OD Axial @ Support
1	165	Prevent @ Miscellaneous
3	165	Prevent @ Miscellaneous
1	173	Prevent @ Miscellaneous
14	174	OD Axial @ Freespan

**TABLE 8 – SONGS U2C12 Refueling Outage Tubes Sleeved
STEAM GENERATOR E-089**


Row	Column	Reason for Sleeving Tube (per Table 3)
39	37	ID Circ @ TSH
16	42	ID Circ @ TSH
47	45	ID Axial below TSH
100	46	OD Circ @ TSH
24	48	ID Circ @ TSH
29	49	OD Circ @ TSH
47	49	OD Circ @ TSH
50	52	OD Circ @ TSH
39	53	OD Axial @ Sludge Pile TSH
24	54	OD Circ @ TSH
30	54	OD Circ @ TSH
44	54	OD Axial @ Sludge Pile TSH
22	60	ID Axial below TSH
71	63	ID Circ @ TSH
31	65	OD Axial @ Sludge Pile TSH
22	66	ID Axial below TSH
70	66	ID Circ @ TSH
55	69	OD Axial @ Sludge Pile TSH
57	69	OD Axial @ Sludge Pile TSH
74	72	OD Circ @ TSH
114	76	OD Circ @ TSH
57	81	OD Axial @ Sludge Pile TSH
65	81	OD Axial @ Sludge Pile TSH
86	82	ID Circ @ TSH
63	91	ID Axial below TSH
61	93	OD Circ @ TSH
85	93	ID Circ @ TSH
84	96	ID Circ @ TSH
59	99	OD Circ @ TSH
41	103	ID Axial below TSH
57	105	ID Circ @ TSH
75	105	OD Circ @ TSH
37	107	ID Axial below TSH
24	112	OD Circ @ TSH
25	115	OD Circ @ TSH
29	115	ID Axial below TSH

**TABLE 8 (CONT.) – SONGS U2C12 Refueling Outage Tubes Sleeved
STEAM GENERATOR E-089**

Row	Column	Reason for Sleeving Tube (per Table 3)
93	115	ID Axial below TSH
26	118	OD Circ @ TSH
28	118	OD Circ @ TSH
85	119	ID Circ @ TSH
85	123	ID Circ @ TSH
13	139	ID Circ below TSH
11	141	ID Circ @ TSH

Appendix 1
Steam Generator Reference Information

**Steam Generator
CE Model 3410 Tube Support Drawing**




**STEAM GENERATOR TUBE SUPPORT INTERSECTIONS
ABOVE THE 7TH (FULL) EGGCRATE SUPPORT**

ROW	STRUCTURES														
	08H	09H	10H	DBH	VH1	VH2	VH3	VSM	VC3	VC2	VC1	DBC	10C	09C	08C
122-147	08H	09H	10H	DBH	VH1	VH2	VH3	VSM	VC3	VC2	VC1	DBC	10C	09C	08C
120-121*	08H	09H		DBH	VH1	VH2	VH3	VSM	VC3	VC2	VC1	DBC	10C	09C	08C
115-119	08H	09H		DBH	VH1	VH2	VH3	VSM	VC3	VC2	VC1	DBC		09C	08C
86-114	08H	09H		DBH		VH2	VH3	VSM	VC3	VC2		DBC		09C	08C
84-85*	08H	09H		DBH		VH2	VH3	VSM	VC3	VC2		DBC		09C	08C
83	08H			DBH		VH2	VH3	VSM	VC3	VC2		DBC			08C
51-82	08H			DBH			VH3	VSM	VC3			DBC			08C
49-50*	08H			DBH				VSM				DBC			08C
19-48				DBH				VSM				DBC			
1-18				DBH								DBC			

* Indicates those rows adjacent to scallop bars

SOUTHERN CALIFORNIA EDISON, SAN ONOFRE

CE MODEL 3410 STEAM GENERATOR



Appendix 2

Legend for Appendices 3 and 4

**List of Abbreviations and Format Used to Describe
Indications from Rotating Probe Testing**

"I-Code" Abbreviations		Explanation of the Abbreviations
SCI		Single Circumferential Indication
MCI		Multiple Circumferential Indications
SAI		Single Axial Indication
MAI		Multiple Axial Indications
MMI		Mixed Mode Indications
SVI		Single Volumetric Indication (i.e. no special axial or circumferential aspect)
MVI		Multiple Volumetric Indications (i.e. no special axial or circumferential aspect)

Format

In Appendices 3 and 4, a single line of data is associated with each individual rotating probe indication. Below is a descriptive example of the format.

ROW	COL	VOLTS	DEG	CHN	IND	%TW	LOCATION	EXT	EXT	UTIL 1	UTIL 2
4	12	+P VOLTS	+P DEG	CH#	CODE	%	LOCATION	EXT	EXT	PAN VOLTS	+P LEN

1. All "I-Code" indications require a single line entry. The example above displays the form of a Resolution Report line. The VOLTS field contains the Plus-Point P-to-P voltage of the largest, most representative response. The DEG field contains the corresponding phase angle. The CHN field contains the reporting channel (i.e. the appropriate 300kHz Plus-Point channel). The IND field contains the appropriate 3-letter code (see list above). The %TW field indicates the percent wall loss for wear indications. The LOCATION field contains the abbreviation for the referenced landmark and the (FROM-TO) distance for the indication. The EXT fields contain the landmarks of the beginning and end of the test extent. The UTIL 1 field contains the 300kHz pancake P-to-P voltage of the largest, most representative response. The UTIL 2 field contains the measured Plus-Point length of the indications. Exceptions to this general guidance is provided in paragraphs 2 and 3 below.
2. For axial indications of extended length, the location should be ranged (FROM-TO) in the LOCATION field. If the range of such an indication includes any part of a support structure, it should be references from that landmark.
3. For "I-Code" indications which have both axial and circumferential extent (i.e. SVI, MVI, and MMI) the location should be ranged in the LOCATION field (as above) and the UTIL 2 field should contain the circumferential length.

Appendix 3
Inspection Summary
Steam Generator E-088

SG88 - MAI, MCI, MMI, MVI, SAI, SCI, SVI, 0-100%TWD

QUERY: QueryM1

ROW	LIN	VOLTS	DEG	CHN	IND	%TW	LOCATION	EXT	EXT	UTIL	1 UTIL	2	CAL #	LEG	PROBE		
4	12	0.23	104	2	SAI		TSH	+3.51			TSH	TSH	0.21	0.12	47	HOT	600PP
4	162	3.04	26	4	SAI		TSH	-7.10			TSH	TSH	5.60	0.24	180	HOT	580PP
6	46	0.46	22	P 1	SCI		TSH	-4.32			TSH	TSH	0.84	0.20	33	HOT	600PP
8	36	0.45	21	P 1	SCI		TSH	-5.27			TSH	TSH	0.21	0.22	36	HOT	600PP
10	120	1.75	41	P 1	SCI		TSH	-7.86			TSH	TSH	3.94	0.22	182	HOT	580PP
		1.16	26	4	MVI		TSH	-9.17	TO-8.97		TSH	TSH	1.55	0.69	182	HOT	580PP
		0.46	51	P 1	MCI		TSH	-7.43	TO-6.62		TSH	TSH	3.13	0.46	182	HOT	580PP
10	126	0.22	35	P 2	TWD	11	05H	+0.76			TEC	TEH	LAR		13	HOT	600UL
12	62	0.34	21	P 1	SCI		TSH	-1.77			TSH	TSH	0.13	0.19	58	HOT	600PP
12	138	0.27	25	P 1	SCI		TSH	-0.02			TSH	TSH	0.22	0.35	46	HOT	600PP
13	9	0.61	81	P 2	TWD	24	05H	-0.10			TEH	TEC			46	COLD	600UL
13	61	0.39	115	2	SAI		06H	+0.49			06H	06H	1.34	0.27	115	HOT	580PP
15	13	0.29	98	2	SAI		06H	+0.30			06H	06H	0.18	0.53	123	HOT	580PP
15	135	0.42	19	P 1	SCI		TSH	-2.66			TSH	TSH	0.28	0.16	41	HOT	600PP
16	20	0.28	128	P 2	TWD	12	DBC	+1.25			TEH	TEC			49	COLD	600UL
16	44	0.27	22	P 1	SCI		TSH	-0.09			TSH	TSH	0.00	0.19	32	HOT	600PP
17	27	0.55	11	2	SAI		TSH	-2.82			TSH	TSH	0.51	0.19	39	HOT	600PP
17	35	0.44	17	P 1	SCI		TSH	-0.09			TSH	TSH	0.16	0.19	36	HOT	600PP
17	61	1.01	20	2	SAI		TSH	-1.11			TSH	TSH	0.65	0.18	53	HOT	600PP
18	36	0.72	22	P 1	SCI		TSH	-0.08			TSH	TSH	0.49	0.19	37	HOT	600PP
18	44	0.25	92	P 2	TWD	8	DBH	-1.75			TEH	TEC			1	COLD	600UL
18	58	0.69	43	2	SAI		07H	-0.11			07H	07H	0.56	0.11	188	HOT	520PP
18	118	0.49	7	2	SAI		06H	+0.26			06H	06H	0.00	0.26	138	HOT	580PP
18	124	0.15	91	2	SAI		01H	+8.39			01H	01H	0.00	0.39	135	HOT	580PP
18	126	0.38	24	P 1	SCI		TSH	-0.12			TSH	TSH	0.69	0.22	76	HOT	600PP
19	39	0.29	25	P 1	SCI		TSH	-0.11			TSH	TSH	0.17	0.21	37	HOT	600PP
21	49	1.07	16	2	SAI		07H	-0.52			07H	07H	0.00	0.20	107	HOT	580PP
21	159	0.28	93	2	SAI		06H	+0.87			06H	06H	0.71	0.18	111	HOT	580PP
		0.43	134	P 2	TWD	16	06H	+0.87			TEH	TEC			30	COLD	600UL
22	112	0.53	14	2	SAI		TSH	-0.58			TSH	TSH	0.47	0.18	68	HOT	600PP
22	116	0.65	13	2	SAI		06H	+0.02			06H	06H	0.00	0.18	138	HOT	580PP
22	166	0.09	124	2	SAI		06H	+4.48			06H	06H	0.00	0.32	105	HOT	580PP
		0.14	114	2	SAI		06H	+7.50			06H	06H	0.19	0.67	105	HOT	580PP
		0.07	74	2	SAI		06H	+10.97			06H	06H	0.00	0.45	105	HOT	580PP
		0.11	126	2	SAI		06H	+17.60			06H	06H	0.00	0.48	105	HOT	580PP
22	168	0.14	119	2	SAI		06H	+13.00			06H	06H	0.00	0.27	105	HOT	580PP
23	109	0.33	116	P 2	TWD	14	VSM	+0.76			TEC	TEH			19	HOT	600UL
23	113	0.61	18	2	SAI		TSH	-1.16			TSH	TSH	1.22	0.16	67	HOT	600PP
		0.64	14	2	SAI		TSH	-0.51			TSH	TSH	1.21	0.16	67	HOT	600PP
24	14	0.33	66	P 2	TWD	13	VSM	+0.88			TEH	TEC			49	COLD	600UL
24	48	0.47	21	P 1	SCI		TSH	-2.07			TSH	TSH	0.58	0.16	48	HOT	600PP

SG88 - MAI, MCI, MMI, MVI, SAI, SCI, SVI, 0-100%TWD

QUERY: QueryM1

ROW	LINE	VOLTS	DEG	CHN	IND	%TW	LOCATION	EXT	EXT	UTIL	1	UTIL	2	CAL	#	LEG	PROBE
24	170	0.19	117	2	SAI	02H	+0.33	02H	02H	0.59	0.24	106	HOT		580PP		
		0.20	104	2	SAI	06H	-0.33	06H	06H	0.00	0.13	106	HOT		580PP		
		0.20	133	2	SAI	06H	-0.12	06H	06H	0.00	0.16	106	HOT		580PP		
		0.24	141	2	SAI	06H	+0.12	06H	06H	0.00	0.16	106	HOT		580PP		
25	49	0.42	14	P	1	SCI	TSH	-0.05	TSH	TSH	0.27	0.14	47	HOT		600PP	
25	119	0.56	23	P	1	MCI	TSH	-0.21	TSH	TSH	0.32	0.24	71	HOT		580PP	
27	115	0.31	125	2	SAI	05H	+0.01	05H	05H	0.00	0.35	143	HOT		580PP		
		0.17	94	2	SAI	05H	-0.48	05H	05H	0.00	0.22	143	HOT		580PP		
27	121	0.23	16	P	1	SCI	TSH	-0.04	TSH	TSH	0.31	0.18	174	HOT		580PP	
27	173	0.40	134	P	2	TWD	18	04H	TEH	TEC			36	COLD		600UL	
28	112	0.43	98	P	2	TWD	15	07H	TEC	TEH			20	HOT		600UL	
		0.25	101	2	SAI	07H	+0.80	07H	07H	0.00	0.14	142	HOT		580PP		
							-0.81										
28	114	0.44	17	2	SAI	TSH	-3.43	TSH	TSH	0.54	0.25	71	HOT		580PP		
29	115	0.26	134	2	SAI	05H	-0.07	05H	05H	0.00	0.57	142	HOT		580PP		
30	68	0.63	15	2	SAI	TSH	-0.09	TSH	TSH	0.73	0.25	58	HOT		600PP		
30	70	0.62	18	2	SAI	TSH	-0.03	TSH	TSH	0.33	0.17	58	HOT		600PP		
31	11	0.47	115	P	2	TWD	20	DBH	TEH	TEC			46	COLD		600UL	
31	109	0.85	18	2	SAI	06H	-0.53	06H	06H	0.00	0.24	142	HOT		580PP		
32	60	0.34	49	P	2	TWD	13	VSM	TEC	TEH			15	HOT		600UL	
32	164	0.22	95	2	SAI	06H	+0.37	06H	06H	0.64	0.33	111	HOT		580PP		
33	69	0.30	111	2	SAI	07H	-0.12	07H	07H	0.00	0.19	188	HOT		520PP		
33	71	0.46	92	P	2	TWD	16	DBC	TSC	TEH			31	HOT		600UL	
34	72	0.59	23	P	2	TWD	20	DBC	TEC	TEH			30	HOT		600UL	
34	116	0.24	75	P	2	TWD	11	VSM	TEC	TEH			19	HOT		600UL	
34	122	0.86	18	2	SAI	TSH	-4.50	TSH	TSH	0.79	0.18	71	HOT		580PP		
35	25	0.61	132	P	2	TWD	21	VSM	TEH	TEC			50	COLD		600UL	
35	59	0.64	83	P	2	TWD	22	VSM	TEC	TEH			15	HOT		600UL	
36	58	0.53	155	P	2	TWD	19	VSM	TEC	TEH			15	HOT		600UL	
36	68	0.45	18	P	1	SCI	TSH	-1.26	TSH	TSH	0.00	0.21	58	HOT		600PP	
36	102	0.96	82	P	2	TWD	29	DBC	TSC	TEH			34	HOT		600UL	
36	104	0.94	106	P	2	TWD	27	DBH	STH	TEC			42	COLD		600UL	
36	106	0.31	16	2	SAI	TSH	-1.11	TSH	TSH	0.95	0.16	67	HOT		600PP		
36	108	0.96	22	2	SAI	TSH	-3.98	TSH	TSH	1.30	0.16	67	HOT		600PP		
36	110	0.34	148	P	2	TWD	15	VSM	TEC	TEH			19	HOT		600UL	
37	13	0.19	92	2	SAI	06H	+2.03	06H	06H	0.22	0.17	123	HOT		580PP		
37	47	0.43	134	P	2	TWD	15	VSM	TEC	TEH			12	HOT		600UL	
37	61	0.66	121	P	2	TWD	22	VSM	TEC	TEH			15	HOT		600UL	
37	69	0.99	16	2	MAI	TSH	-1.28	TSH	TSH	0.66	0.17	57	HOT		600PP		
37	119	1.90	23	4	SAI	TEH	+9.99	TEH	TEH	3.39	0.46	175	HOT		580PP		
38	74	0.67	21	P	2	TWD	22	DBC	TEC	TEH			30	HOT		600UL	

SG88 - MAI, MCI, MMI, MVI, SAI, SCI, SVI, 0-100%TWD

QUERY: QueryM1

ROW	LIN	VOLTS	DEG	CHN	IND	%TW	LOCATION	EXT	EXT	UTIL	1 UTIL	2 CAL	# LEG	PROBE	
38	102	0.34	109	P 2	TWD	13	DBC	+1.59	TSC	TEH		34	HOT	600UL	
		0.81	123	P 2	TWD	26	DBC	+1.93	TSC	TEH		34	HOT	600UL	
39	13	0.33	132	P 2	TWD	15	VSM	+0.19	TEH	TEC		46	COLD	600UL	
39	101	0.99	126	P 2	TWD	30	DBC	+1.97	TEC	TEH		34	HOT	600UL	
39	103	0.43	80	P 2	TWD	14	DBC	+1.80	STH	TEC		42	COLD	600UL	
39	121	0.23	23	P 1	SCI		TSH	-0.14	TSH	TSH	0.51	0.19	72	HOT	600PP
39	127	0.36	61	P 2	TWD	17	VSM	-0.88	TEC	TEH		13	HOT	600UL	
40	122	0.49	65	P 2	TWD	17	VSM	-0.85	TEC	TEH		14	HOT	600UL	
41	73	0.31	92	P 2	TWD	11	VSM	+0.89	TEC	TEH		31	HOT	600UL	
41	101	0.35	130	P 2	TWD	13	VSM	-0.81	TEC	TEH		35	HOT	600UL	
41	103	0.22	15	2	SAI		TSH	-0.44	TSH	TSH	0.56	0.17	59	HOT	600PP
41	113	0.40	71	P 2	TWD	17	VSM	-0.91	TEC	TEH		26	HOT	600UL	
42	74	0.42	107	P 2	TWD	15	DBC	+1.86	TEC	TEH		31	HOT	600UL	
42	106	0.48	107	P 2	TWD	18	VSM	-0.83	TSC	TEH		34	HOT	600UL	
43	19	0.60	128	P 2	TWD	21	02H	+0.85	TEH	TEC		48	COLD	600UL	
43	51	0.95	122	P 2	TWD	27	VSM	+0.82	TEC	TEH		12	HOT	600UL	
43	75	0.62	126	P 2	TWD	20	DBC	+1.99	TEC	TEH		31	HOT	600UL	
		0.81	114	P 2	TWD	24	VSM	+0.86	TEC	TEH		31	HOT	600UL	
43	101	0.30	108	P 2	TWD	11	DBC	-1.63	TEC	TEH		34	HOT	600UL	
43	125	0.37	112	P 2	TWD	17	VSM	-0.83	TEC	TEH		13	HOT	600UL	
44	58	0.48	118	P 2	TWD	18	VSM	+0.84	TEC	TEH		15	HOT	600UL	
44	76	0.49	13	2	SAI		TSH	-0.90	TSH	TSH	0.62	0.32	69	HOT	600PP
		0.35	14	2	SAI		TSH	-1.81	TSH	TSH	0.23	0.12	69	HOT	600PP
		0.35	10	2	SAI		TSH	-2.06	TSH	TSH	0.56	0.29	69	HOT	600PP
44	98	0.51	109	P 2	TWD	16	01H	-0.30	TEC	TEH		35	HOT	600UL	
44	100	0.33	119	P 2	TWD	13	DBC	-1.51	TEC	TEH		34	HOT	600UL	
		1.40	169	P 2	TWD	36	DBC	+1.82	TEC	TEH		34	HOT	600UL	
44	124	0.33	47	P 2	TWD	12	VSM	-0.97	TEC	TEH		14	HOT	600UL	
45	55	0.37	125	P 1	SCI		TSH	+0.07	TSH	TSH	0.00	0.57	54	HOT	600PP
45	73	0.41	130	P 2	TWD	13	DBC	-1.61	STH	TEC		40	COLD	600UL	
45	75	0.85	112	P 2	TWD	25	DBC	+1.95	TEC	TEH		30	HOT	600UL	
		0.87	106	P 2	TWD	26	DBH	-1.76	TEC	TEH		30	HOT	600UL	
46	72	0.39	25	2	SAI		TSH	-1.37	TSH	TSH	0.71	0.16	67	HOT	600PP
46	74	0.62	87	P 2	TWD	19	DBC	+1.78	TEC	TEH		31	HOT	600UL	
		1.23	97	P 2	TWD	30	VSM	-0.87	TEC	TEH		31	HOT	600UL	
		0.32	133	P 2	TWD	11	VSM	+0.83	TEC	TEH		31	HOT	600UL	
46	76	0.70	18	P 2	TWD	22	DBH	+2.01	TEC	TEH		30	HOT	600UL	
46	78	1.11	129	P 2	TWD	30	DBC	+2.25	TEC	TEH		30	HOT	600UL	
46	98	0.94	76	P 2	TWD	29	DBH	-1.92	TEC	TEH		34	HOT	600UL	
46	116	0.43	20	P 1	SCI		TSH	-0.03	TSH	TSH	0.34	0.16	72	HOT	600PP
		0.71	38	P 2	TWD	23	VSM	-0.80	TEC	TEH		20	HOT	600UL	
47	99	0.50	62	P 2	TWD	18	DBC	-1.91	TEC	TEH		34	HOT	600UL	
		1.44	109	P 2	TWD	37	DBH	-2.25	TEC	TEH		34	HOT	600UL	

SG88 - MAI, MCI, MMI, MVI, SAI, SCI, SVI, 0-100%TWD

QUERY: QueryM1

ROW	LINE	VOLTS	DEG	CHN	IND	%TW	LOCATION	EXT	EXT	UTIL	1 UTIL	2 CAL	#	LEG	PROBE
		0.32	98	P 2	TWD 14	DBC	+2.15	TEC	TEH.		34	HOT		600UL	
47	109	0.21	134	P 2	TWD 9	VSM	+0.98	STH	TEC		42	COLD		600UL	
47	123	0.27	21	P 1	MCI	TSH	-0.08	TSH	TSH	0.20	0.20	76	HOT	600PP	
47	143	0.37	138	P 2	TWD 15	VSM	-0.81	TEH	TEC		23	COLD		600UL	
48	58	0.39	17	P 1	SCI	TSH	-3.20	TSH	TSH	0.40	0.16	53	HOT	600PP	
48	68	0.38	118	P 2	TWD 14	VSM	+0.78	TEC	TEH		17	HOT		600UL	
48	108	0.52	92	P 2	TWD 17	VSM	-0.20	TEC	TEH		10	HOT		600UL	
		0.48	74	P 2	TWD 16	VSM	-0.77	TEC	TEH		10	HOT		600UL	
49	31	0.43.	92	P 2	TWD 16	08C	-1.14	TEH	TEC		50	COLD		600UL	
49	65	0.21	91	2	SAI	TSH	+0.18	TSH	TSH	0.00	0.18	57	HOT	600PP	
		0.25	107	2	SAI	TSH	+0.40	TSH	TSH	0.00	0.25	57	HOT	600PP	
49	71	0.30	11	2	SAI	TSH	-0.63	TSH	TSH	0.20	0.12	68	HOT	600PP	
		0.33	14	2	SAI	TSH	-0.46	TSH	TSH	0.10	0.14	68	HOT	600PP	
		0.51	82	P 2	TWD 18	VSM	-0.82	TEC	TEH		30	HOT		600UL	
49	75	0.30	108	P 2	TWD 11	DBH	-1.96	TEC	TEH		30	HOT		600UL	
49	109	0.80	19	2	SAI	TSH	-2.59	TSH	TSH	1.00	0.16	67	HOT	600PP	
50	8	0.36	143	P 2	TWD 16	VSM	+0.78	TEH	TEC		46	COLD		600UL	
50	66	0.70	130	P 2	TWD 24	08C	+1.08	STH	TEC		41	COLD		600UL	
50	76	0.72	90	P 2	TWD 23	DBC	-1.81	TEC	TEH		30	HOT		600UL	
50	98	0.32	42	P 2	TWD 12	VSM	-0.89	TEC	TEH		34	HOT		600UL	
50	110	0.47	73	P 2	TWD 20	08H	+1.23	TEC	TEH	LAR		26	HOT	600UL	
51	77	0.49	87	P 2	TWD 16	DBC	-2.00	TEC	TEH		31	HOT		600UL	
51	79	1.14	120	P 2	TWD 31	DBC	-1.76	TEC	TEH		30	HOT		600UL	
		0.70	44	P 2	TWD 22	DBC	+1.88	TEC	TEH		30	HOT		600UL	
		0.30	40	P 2	TWD 11	DBH	+1.41	TEC	TEH		30	HOT		600UL	
51	99	0.69	90	P 2	TWD 24	DBH	-2.05	TEC	TEH		34	HOT		600UL	
51	105	0.41	14	2	SAI	TSH	-1.33	TSH	TSH	0.00	0.20	59	HOT	600PP	
		0.39	22	2	SAI	TSH	-1.17	TSH	TSH	0.53	0.17	59	HOT	600PP	
		0.32	9	2	SAI	TSH	-0.96	TSH	TSH	0.18	0.15	59	HOT	600PP	
51	111	0.62	11	2	SAI	TSH	-4.45	TSH	TSH	0.83	0.19	67	HOT	600PP	
51	163	0.52	63	P 2	TWD 19	VH3	+0.89	TEH	TEC		35	COLD		600UL	
52	68	0.53	125	P 2	TWD 19	VSM	+0.04	TEC	TEH		17	HOT		600UL	
52	90	1.05	69	P 2	TWD 27	DBH	-1.91	STH	TEC		38	COLD		600UL	
52	94	0.49	124	P 2	TWD 18	DBC	-1.77	TEC	TEH		34	HOT		600UL	
52	96	0.49	65	P 2	TWD 18	DBH	-2.14	TEC	TEH		34	HOT		600UL	
52	104	0.58	16	2	SAI	TSH	-1.08	TSH	TSH	0.48	0.13	59	HOT	600PP	
53	81	1.15	101	P 2	TWD 31	DBH	-1.61	TEC	TEH		30	HOT		600UL	
54	8	0.57	120	P 2	TWD 23	01H	+0.08	TEH	TEC	LAR		46	COLD	600UL	
		0.15	24	P 2	TWD 8	01H	-1.01	TEH	TEC	LAR		46	COLD	600UL	
54	64	0.70	16	2	SAI	TSH	-1.63	TSH	TSH	0.49	0.15	58	HOT	600PP	
		0.79	17	2	SAI	TSH	-3.48	TSH	TSH	0.62	0.15	58	HOT	600PP	
54	74	0.56	16	2	SAI	TSH	-1.55	TSH	TSH	0.80	0.15	70	HOT	580PP	
		0.49	13	2	SAI	TSH	-1.32	TSH	TSH	0.82	0.20	70	HOT	580PP	

SG88 - MAI, MCI, MMI, MVI, SAI, SCI, SVI, 0-100%TWD

QUERY: QueryM1

ROW	LINE	VOLTS	DEG	CHN	IND	%TW	LOCATION	EXT	EXT	UTIL	1 UTIL	2 CAL	# LEG	PROBE
54	76	0.46	137	P 2	TWD	16	DBC	-1.71	TEC TEH			30	HOT	600UL
54	90	1.59	79	P 2	TWD	35	DBH	-2.10	STH TEC			38	COLD	600UL
		0.84	132	P 2	TWD	23	DBH	+1.75	STH TEC			38	COLD	600UL
		0.18	8	P 2	TWD	6	DBC	+1.74	STH TEC			38	COLD	600UL
54	96	0.64	78	P 2	TWD	19	DBH	-1.61	STH TEC			38	COLD	600UL
54	108	0.14	132	2	SAI		02H	+7.35	02H 02H	0.00	0.22	150	HOT	580PP
55	83	0.67	119	P 2	TWD	19	DBH	-1.89	STH TEC			40	COLD	600UL
		0.20	162	P 2	TWD	7	DBH	+1.85	01H TEC			40	COLD	600UL
55	85	0.33	14	2	SAI		TSH	-1.10	TSH TSH	0.30	0.21	74	HOT	580PP
55	89	0.85	95	P 2	TWD	24	DBC	-1.54	STH TEC			38	COLD	600UL
		0.56	170	P 2	TWD	17	DBC	+1.47	STH TEC			38	COLD	600UL
55	91	0.39	93	P 2	TWD	15	DBH	-1.99	TEC TEH			34	HOT	600UL
55	117	0.24	93	P 1	SCI		TSH	-0.08	TSH TSH	0.65	0.31	71	HOT	580PP
56	80	0.47	50	P 2	TWD	16	DBC	-1.95	TEC TEH			31	HOT	600UL
56	86	1.41	91	P 2	TWD	36	DBH	-2.00	TEC TEH			34	HOT	600UL
56	88	0.70	25	2	SAI		TSH	-1.40	TSH TSH	0.44	0.16	64	HOT	600PP
		0.71	85	P 2	TWD	22	DBC	-1.71	TEC TEH			35	HOT	600UL
56	90	0.72	28	P 2	TWD	24	DBH	+1.27	TEC TEH			34	HOT	600UL
		1.01	52	P 2	TWD	30	DBH	-2.15	TEC TEH			34	HOT	600UL
56	92	0.38	23	2	SAI		TSH	-0.60	TSH TSH	0.93	0.16	63	HOT	600PP
57	25	0.63	56	P 2	TWD	21	VH3	-0.79	TEH TEC			51	COLD	600UL
57	69	0.33	118	P 2	TWD	11	VH3	+0.82	TEC TEH			17	HOT	600UL
57	81	0.43	124	P 2	TWD	15	DBH	-1.49	TEC TEH			30	HOT	600UL
57	111	0.76	20	2	SAI		TSH	-4.12	TSH TSH	0.81	0.16	67	HOT	600PP
57	167	0.59	150	P 2	TWD	22	02C	+0.84	TEH TEC			34	COLD	600UL
58	70	0.40	97	P 2	TWD	14	VSM	-0.82	TEC TEH			17	HOT	600UL
58	88	0.29	10	2	SAI		TSH	-0.98	TSH TSH	0.27	0.14	63	HOT	600PP
		0.32	89	P 2	TWD	12	DBC	-1.73	TEC TEH			34	HOT	600UL
58	134	0.33	31	P 1	SCI		TSH	-0.05	TSH TSH	0.23	0.20	42	HOT	600PP
59	87	0.50	68	P 2	TWD	17	DBH	-1.99	TEC TEH			35	HOT	600UL
59	111	0.32	91	P 2	TWD	12	01H	+1.19	STH TEC			42	COLD	600UL
59	143	0.41	37	P 2	TWD	17	VH3	-0.57	TEH TEC			23	COLD	600UL
61	31	0.29	84	P 2	TWD	11	VH3	+1.03	TEH TEC			50	COLD	600UL
61	103	0.32	23	P 1	SCI		TSH	-0.17	TSH TSH	0.86	0.21	59	HOT	600PP
61	125	0.35	130	P 2	TWD	12	VC3	-1.08	TEC TEH			14	HOT	600UL
62	62	0.42	19	P 1	MCI		TSH	-0.09	TSH TSH	0.10	0.17	57	HOT	600PP
62	70	0.40	133	P 2	TWD	14	VSM	+0.00	TEC TEH			17	HOT	600UL
62	72	0.22	13	P 1	SCI		TSH	-0.11	TSH TSH	0.26	0.16	69	HOT	600PP
64	80	0.57	157	P 2	TWD	18	DBH	+1.62	TEC TEH			31	HOT	600UL
		0.39	152	P 2	TWD	13	VSM	-0.76	TEC TEH			31	HOT	600UL
64	98	0.15	105	2	SAI		TSH	+0.11	TSH TSH	0.00	0.13	59	HOT	600PP
65	69	0.56	16	P 1	SCI		TSH	-0.14	TSH TSH	0.00	0.25	58	HOT	600PP

SG88 - MAI, MCI, MMI, MVI, SAI, SCI, SVI, 0-100%TWD

QUERY: QueryM1

ROW	LINE	VOLTS	DEG	CHN	IND	%TW	LOCATION	EXT	EXT	UTIL	1 UTIL	2 CAL	# LEG	PROBE
65	97	0.42	95	P 2	TWD 14	02H	-1.13	TEC	TEH		35	HOT	600UL	
65	113	0.42	30	P 1	SCI	TSH	-0.11	TSH	TSH	0.57	0.22	67	HOT	600PP
65	119	0.41	22	P 1	SCI	TSH	-0.08	TSH	TSH	0.45	0.19	72	HOT	600PP
65	121	0.19	24	P 1	SCI	TSH	-0.14	TSH	TSH	0.12	0.16	72	HOT	600PP
66	48	0.57	123	P 2	TWD 19	VSM	-0.82	TEC	TEH		12	HOT	600UL	
67	83	0.18	95	4	MAI	TSH	+0.59	TSH	TSH	0.00	0.17	170	HOT	580PP
67	85	0.79	52	P 2	TWD 23	DBC	-1.91	TEC	TEH		35	HOT	600UL	
67	109	0.18	118	P 1	SCI	TSH	+0.03	TSH	TSH	0.00	0.20	68	HOT	600PP
67	121	0.17	90	P 2	TWD 8	VSM	+0.81	TEC	TEH		19	HOT	600UL	
67	129	0.23	148	P 2	TWD 11	VH3	+0.00	TEC	TEH		9	HOT	600UL	
67	159	0.47	118	P 2	TWD 17	VC3	-0.31	TEH	TEC		29	COLD	600UL	
	0.32	122	P 2	TWD 12	VH3	+0.81	TEH	TEC		29	COLD	600UL		
67	165	0.79	120	P 2	TWD 27	VH3	-0.83	TEH	TEC		34	COLD	600UL	
68	70	0.42	20	P 1	SCI	TSH	-0.08	TSH	TSH	0.09	0.19	58	HOT	600PP
68	74	0.18	22	P 1	SCI	TSH	-0.07	TSH	TSH	0.18	0.19	69	HOT	600PP
68	90	0.24	98	2	SAI	TSH	+0.55	TSH	TSH	0.17	0.19	64	HOT	600PP
68	102	0.87	27	P 1	MCI	TSH	-0.18	TSH	TSH	0.87	0.21	59	HOT	600PP
68	146	0.50	110	P 2	TWD 21	VC3	-0.86	TEH	TEC		25	COLD	600UL	
69	163	0.36	94	P 2	TWD 14	VSM	+0.83	TEH	TEC		34	COLD	600UL	
70	70	0.50	86	P 2	TWD 18	VC3	-0.86	TEC	TEH		17	HOT	600UL	
71	63	0.52	115	P 2	TWD 18	VH3	-0.88	TEC	TEH		17	HOT	600UL	
71	85	0.87	52	P 2	TWD 24	DBC	-1.91	TEC	TEH		35	HOT	600UL	
71	89	0.19	132	2	SAI	TSH	+0.85	TSH	TSH	0.24	0.16	63	HOT	600PP
71	97	0.28	76	P 2	TWD 10	01H	+0.88	TEC	TEH		35	HOT	600UL	
72	70	0.36	91	P 2	TWD 13	VC3	-1.10	TEC	TEH		18	HOT	600UL	
72	88	0.54	105	P 2	TWD 20	DBC	-1.82	TEC	TEH		34	HOT	600UL	
72	90	0.60	141	P 2	TWD 19	VSM	+0.86	TEC	TEH		35	HOT	600UL	
72	98	0.45	102	P 2	TWD 17	02H	-1.24	TEC	TEH		34	HOT	600UL	
72	106	0.46	27	P 1	SCI	TSH	-0.12	TSH	TSH	0.19	0.17	60	HOT	600PP
	0.51	83	P 2	TWD 16	VH3	-0.80	TEC	TEH		35	HOT	600UL		
72	118	0.23	68	P 2	TWD 8	VH3	-0.83	TEC	TEH		9	HOT	600UL	
73	73	0.82	119	P 2	TWD 24	VSM	+0.93	TEC	TEH		31	HOT	600UL	
73	133	0.51	131	P 2	TWD 20	VH3	+0.87	TEH	TEC		22	COLD	600UL	
74	82	0.46	127	P 2	TWD 16	VSM	-0.94	TEC	TEH		31	HOT	600UL	
	0.95	140	P 2	TWD 26	VSM	+0.82	TEC	TEH		31	HOT	600UL		
74	100	0.21	79	P 1	MCI	TSH	-0.02	TSH	TSH	0.00	0.45	59	HOT	600PP
74	146	0.75	141	P 2	TWD 23	VH3	-0.83	TEH	TEC		26	COLD	600UL	
	0.72	59	P 2	TWD 23	VC3	-0.95	TEH	TEC		26	COLD	600UL		
	1.02	143	P 2	TWD 28	VC3	+0.85	TEH	TEC		26	COLD	600UL		
74	148	0.26	82	P 2	TWD 11	VH3	-0.86	TEH	TEC		26	COLD	600UL	

SG88 - MAI, MCI, MMI, MVI, SAI, SCI, SVI, 0-100%TWD

QUERY: QueryM1

ROW	LINE	VOLTS	DEG	CHN	IND	%TW	LOCATION	EXT	EXT	UTIL	1 UTIL	2 CAL	#	LEG	PROBE
75	139	0.23	86	P 2	TWD 9	VH3	-0.92	TEH	TEC		23	COLD		600UL	
		0.34	156	P 2	TWD 14	VH3	+0.80	TEH	TEC		23	COLD		600UL	
		0.89	97	P 2	TWD 28	VSM	+0.04	TEH	TEC		23	COLD		600UL	
76	84	0.23	34	P 2	TWD 9	VH3	-0.83	TEC	TEH		30	HOT		600UL	
		0.20	70	P 2	TWD 8	VH3	+0.72	TEC	TEH		30	HOT		600UL	
76	88	0.54	63	P 2	TWD 17	03H	-1.14	TEC	TEH		35	HOT		600UL	
76	90	0.41	45	P 2	TWD 16	VSM	+0.08	TEC	TEH		34	HOT		600UL	
76	100	0.46	142	P 2	TWD 16	VC3	-0.85	TEC	TEH		35	HOT		600UL	
76	134	0.44	127	P 2	TWD 16	VH3	+0.73	TEH	TEC		21	COLD		600UL	
77	31	0.22	122	P 2	TWD 9	VSM	+0.33	TEH	TEC		50	COLD		600UL	
77	33	0.55	79	P 2	TWD 18	VSM	+0.86	TEH	TEC		52	COLD		600UL	
77	93	0.29	110	P 1	SCI	TSH	-0.03	TSH	TSH	0.25	0.25	63	HOT	600PP	
77	97	0.21	130	P 1	SCI	TSH	-0.04	TSH	TSH	0.44	0.38	63	HOT	600PP	
78	22	0.69	105	P 2	TWD 23	VC3	-0.88	TEH	TEC		48	COLD		600UL	
78	26	0.37	95	2	SAI	06H	+0.58	06H	06H	0.65	0.29	123	HOT	580PP	
78	120	0.28	34	P 2	TWD 12	VC3	+0.67	TEC	TEH		9	HOT		600UL	
78	136	0.56	66	P 2	TWD 21	DBH	-1.99	TEH	TEC		22	COLD		600UL	
78	138	0.23	166	P 2	TWD 9	DBC	+1.53	TEH	TEC		24	COLD		600UL	
78	142	0.48	133	P 2	TWD 18	VH3	+0.84	TEH	TEC		24	COLD		600UL	
78	148	0.59	143	P 2	TWD 20	08C	-0.86	TEH	TEC		26	COLD		600UL	
78	154	0.49	134	P 2	TWD 18	VC3	+0.88	TEH	TEC		28	COLD		600UL	
79	73	0.40	97	P 2	TWD 14	VSM	+0.79	TEC	TEH		31	HOT		600UL	
79	103	0.37	28	P 1	SCI	TSH	+0.00	TSH	TSH	0.58	0.30	60	HOT	600PP	
79	143	0.20	134	P 2	TWD 9	DBC	-1.26	TEH	TEC		23	COLD		600UL	
80	24	0.37	97	2	SAI	06H	+0.22	06H	06H	0.31	0.17	123	HOT	580PP	
80	80	0.45	133	P 2	TWD 15	VSM	-0.82	TEC	TEH		31	HOT		600UL	
80	112	0.25	87	P 2	TWD 10	VSM	-0.91	TEC	TEH		9	HOT		600UL	
81	23	0.47	57	P 2	TWD 18	DBC	+1.60	TEH	TEC		49	COLD		600UL	
81	39	0.23	101	P 2	TWD 9	VSM	+0.92	TEH	TEC		3	COLD		600UL	
81	97	0.30	21	P 1	SCI	TSH	-0.10	TSH	TSH	0.43	0.27	63	HOT	600PP	
81	151	0.37	137	P 2	TWD 14	VH3	+0.62	TEH	TEC		28	COLD		600UL	
82	54	0.86	118	P 2	TWD 26	VH3	-0.84	TEC	TEH		11	HOT		600UL	
82	72	0.26	20	P 1	SCI	TSH	-0.15	TSH	TSH	0.39	0.19	69	HOT	600PP	
82	88	0.29	20	P 1	MCI	TSH	-0.11	TSH	TSH	0.33	0.19	73	HOT	600PP	
83	111	0.42	29	P 1	SCI	TSH	-0.12	TSH	TSH	0.19	0.25	67	HOT	600PP	
83	129	0.27	71	P 2	TWD 12	VC2	+0.55	TEC	TEH		9	HOT		600UL	
84	24	0.33	133	2	SAI	06H	-0.29	06H	06H	0.65	0.24	123	HOT	580PP	
84	104	0.40	29	P 2	TWD 15	09H	-1.11	TEC	TEH		34	HOT		600UL	
84	114	0.31	117	P 2	TWD 14	09C	+0.00	TEC	TEH		9	HOT		600UL	

SG88 - MAI, MCI, MMI, MVI, SAI, SCI, SVI, 0-100%TWD

QUERY: QueryM1

ROW	LIN	VOLTS	DEG	CHN	IND	%TW	LOCATION	EXT	EXT	UTIL	1 UTIL	2 CAL	#	LEG	PROBE
85	27	0.26	125	2	SAI	07H	+0.48	07H	07H	0.12	0.24	123	HOT	580PP	
85	67	0.45	96	P 2	TWD 16	VH2	-0.74	TEC	TEH			17	HOT	600UL	
85	91	0.47	123	P 2	TWD 18	09H	-1.15	TEC	TEH			34	HOT	600UL	
85	119	0.39	73	P 2	TWD 16	09H	+1.50	TEC	TEH	LOCOK		9	HOT	600UL	
85	141	0.47	96	P 2	TWD 18	09H	+1.44	TEH	TEC	LOCOK		23	COLD	600UL	
86	86	0.19	115	P 1	SCI	TSH	+0.05	TSH	TSH	0.00	0.33	170	HOT	580PP	
86	130	0.35	128	P 2	TWD 13	VC2	+0.80	TEH	TEC			21	COLD	600UL	
87	37	0.42	126	P 2	TWD 15	VH2	-0.78	TEH	TEC			5	COLD	600UL	
		0.34	126	P 2	TWD 13	VH2	+0.76	TEH	TEC			5	COLD	600UL	
87	125	0.30	113	P 2	TWD 13	VH2	-0.83	TEC	TEH			9	HOT	600UL	
87	127	0.37	55	P 2	TWD 14	VH2	-0.81	TEC	TEH			9	HOT	600UL	
87	129	0.32	129	P 2	TWD 14	VH2	-0.79	TEC	TEH			9	HOT	600UL	
87	133	0.33	106	2	SAI	06H	-0.02	06H	06H	0.99	0.59	117	HOT	580PP	
88	30	0.25	115	2	SAI	07H	+0.72	07H	07H	0.23	0.35	123	HOT	580PP	
		0.24	101	2	SAI	07H	-0.20	07H	07H	0.33	0.31	123	HOT	580PP	
88	52	0.46	53	P 2	TWD 16	VH2	+0.86	TEC	TEH			11	HOT	600UL	
89	33	0.29	151	P 2	TWD 11	VH2	-0.86	TEH	TEC			52	COLD	600UL	
89	37	0.44	121	P 2	TWD 16	VH2	-0.76	TEH	TEC			5	COLD	600UL	
		0.27	73	P 2	TWD 10	VH2	+0.78	TEH	TEC			5	COLD	600UL	
89	51	0.37	110	P 2	TWD 14	VH3	+0.82	TEC	TEH			11	HOT	600UL	
89	61	0.40	142	P 2	TWD 15	VH3	+0.84	TEC	TEH			15	HOT	600UL	
		0.39	83	P 2	TWD 15	VH3	+0.84	TEC	TEH			15	HOT	600UL	
89	123	0.47	120	P 2	TWD 16	VH2	-0.95	TEC	TEH			10	HOT	600UL	
89	125	0.37	28	P 2	TWD 14	VH2	-0.99	TEC	TEH			9	HOT	600UL	
89	127	0.58	127	P 2	TWD 19	VH2	-0.93	TEC	TEH			10	HOT	600UL	
89	141	0.41	60	P 2	TWD 17	VH2	+0.77	TEH	TEC			23	COLD	600UL	
		0.28	96	P 2	TWD 11	VC2	+0.75	TEH	TEC			23	COLD	600UL	
89	143	0.38	142	P 2	TWD 15	VH2	-0.81	TEH	TEC			23	COLD	600UL	
90	40	0.18	83	2	SAI	07H	-0.53	07H	07H	0.15	0.23	127	HOT	580PP	
90	58	0.46	24	P 1	SCI	TSH	-0.15	TSH	TSH	0.68	0.19	65	HOT	600PP	
90	78	0.57	109	P 2	TWD 20	03H	-1.03	TEH	TEC			7	COLD	600UL	
90	148	0.41	33	P 2	TWD 16	VH2	+0.90	TEH	TEC			19	COLD	600UL	
92	26	0.66	70	P 2	TWD 23	VH2	-0.81	TEH	TEC			55	COLD	600UL	
92	36	0.68	43	P 2	TWD 24	VH2	-0.81	TEH	TEC			55	COLD	600UL	
		0.29	68	P 2	TWD 12	VSM	+0.85	TEH	TEC			55	COLD	600UL	
93	153	0.50	59	P 2	TWD 18	05C	-0.88	TEH	TEC			19	COLD	600UL	
		0.43	78	P 2	TWD 17	03C	+0.91	TEH	TEC			19	COLD	600UL	
94	32	0.44	101	P 2	TWD 17	VH2	-0.84	TEH	TEC			54	COLD	600UL	
94	84	0.31	158	P 2	TWD 12	VH3	+0.84	TEH	TEC			8	COLD	600UL	
94	116	0.35	70	P 2	TWD 15	01H	+0.81	TEC	TEH			1	HOT	600UL	
94	138	0.30	79	P 2	TWD 12	VSM	+0.19	TEH	TEC			19	COLD	600UL	

SG88 - MAI, MCI, MMI, MVI, SAI, SCI, SVI, 0-100%TWD

QUERY: QueryM1

ROW	LINE	VOLTS	DEG	CHN	IND	%TW	LOCATION	EXT	EXT	UTIL	1 UTIL	2 CAL	#	LEG	PROBE
95	39	0.30	123	P 2	TWD	13	VSM	+0.69	TEH	TEC		54	COLD	600UL	
96	30	0.27	109	P 2	TWD	12	06H	+0.80	TEH	TEC		54	COLD	600UL	
96	50	0.46	54	P 2	TWD	18	VC2	+0.80	TEC	TEH		8	HOT	600UL	
96	150	0.53	116	P 2	TWD	19	VH2	-0.96	TEH	TEC		20	COLD	600UL	
97	51	0.32	73	P 2	TWD	13	08C	-0.82	TEC	TEH		7	HOT	600UL	
97	97	0.41	24	P 1	SCI		TSH	-0.11	TSH	TSH	0.23	0.17	78	HOT	580PP
98	74	0.27	163	P 2	TWD	11	VC2	+0.78	TEH	TEC		8	COLD	600UL	
98	88	0.28	140	P 2	TWD	11	VH2	-0.63	TEH	TEC		10	COLD	600UL	
99	51	0.39	90	P 2	TWD	15	VC2	-0.76	TEC	TEH		7	HOT	600UL	
99	121	0.27	115	P 2	TWD	12	VH2	-0.89	TEC	TEH		1	HOT	600UL	
99	123	0.19	113	P 2	TWD	9	VC2	+0.55	TEC	TEH		5	HOT	600UL	
100	120	0.28	65	P 2	TWD	13	05H	-0.24	TEC	TEH		1	HOT	600UL	
100	122	0.26	69	P 2	TWD	10	VH3	-0.84	TEC	TEH		6	HOT	600UL	
101	27	0.31	56	P 2	TWD	13	VH2	+0.75	TEH	TEC		54	COLD	600UL	
101	147	0.52	148	P 2	TWD	19	VSM	-0.66	TEH	TEC		19	COLD	600UL	
102	26	0.39	45	P 2	TWD	16	06H	+0.83	TEH	TEC		55	COLD	600UL	
105	133	0.15	70	2	SAI		08H	-0.41	08H	08H	0.30	0.46	155	HOT	580PP
106	30	0.35	125	P 2	TWD	15	06H	+0.84	TEH	TEC		54	COLD	600UL	
107	97	0.23	140	P 2	TWD	10	VH3	-0.84	TEH	TEC		11	COLD	600UL	
107	115	0.27	35	P 2	TWD	8	VH2	+0.86	07H	TEC		33	COLD	600UL	
107	125	0.21	112	P 2	TWD	7	DBH	-1.61	TEC	TEH		6	HOT	600UL	
108	36	0.35	65	P 2	TWD	15	DBC	-1.64	TEH	TEC		55	COLD	600UL	
110	138	0.37	141	P 2	TWD	14	VC3	-0.88	TEH	TEC		19	COLD	600UL	
111	37	0.61	37	P 2	TWD	22	DBH	+1.07	TEH	TEC		54	COLD	600UL	
111	57	0.38	54	P 2	TWD	15	VH3	-0.80	TEC	TEH		7	HOT	600UL	
111	93	0.22	78	P 2	TWD	9	05H	+0.93	TEH	TEC		11	COLD	600UL	
111	101	0.23	89	P 2	TWD	10	DBH	-0.91	TEH	TEC		44	COLD	600UL	
112	92	0.40	48	P 2	TWD	16	VH2	-0.77	TEH	TEC		11	COLD	600UL	
112	144	1.00	165	P 2	TWD	28	DBH	+2.04	TEH	TEC		20	COLD	600UL	
113	37	0.31	118	P 2	TWD	13	VH2	-0.97	TEH	TEC		55	COLD	600UL	
113	39	0.45	130	P 2	TWD	18	DBH	+1.79	TEH	TEC		55	COLD	600UL	
113	41	0.54	113	P 2	TWD	20	VH2	-0.59	TEH	TEC		53	COLD	600UL	
113	99	0.31	138	P 2	TWD	12	VH2	-0.84	TEH	TEC		12	COLD	600UL	
114	96	0.30	156	P 2	TWD	12	VH3	-0.79	TEH	TEC		12	COLD	600UL	
114	108	0.14	126	P 1	SCI		TSH	+0.03	TSH	TSH	0.00	0.18	86	HOT	580PP
114	110	0.32	94	P 2	TWD	14	DBH	-1.75	TEC	TEH		1	HOT	600UL	
116	102	0.42	125	P 2	TWD	17	DBH	+0.65	TEH	TEC		11	COLD	600UL	

SG88 - MAI, MCI, MMI, MVI, SAI, SCI, SVI, 0-100%TWD

QUERY: QueryM1

ROW	LIN	VOLTS	DEG	CHN	IND	%TW	LOCATION	EXT	EXT	UTIL	1 UTIL	2	CAL #	LEG	PROBE
118	88	0.40	125	P 2	TWD 15	VH1	-0.71	TEH	TEC		10	COLD	600UL		
		0.36	121	P 2	TWD 14	VH1	+0.71	TEH	TEC		10	COLD	600UL		
119	39	0.27	152	P 2	TWD 11	VH1	-0.92	TEH	TEC		54	COLD	600UL		
119	41	0.34	138	P 2	TWD 12	VH1	-0.82	TEH	TEC		52	COLD	600UL		
119	55	0.35	95	P 2	TWD 14	DBH	+1.69	TEC	TEH		7	HOT	600UL		
119	59	0.40	132	P 2	TWD 14	VH1	-1.01	TEC	TEH		3	HOT	600UL		
119	61	0.36	136	P 2	TWD 13	VH1	-1.02	TEC	TEH		3	HOT	600UL		
119	65	0.32	126	P 2	TWD 12	VH1	-1.17	TEC	TEH		3	HOT	600UL		
119	67	0.41	136	P 2	TWD 15	VH1	-0.99	TEC	TEH		3	HOT	600UL		
119	79	0.50	114	P 2	TWD 19	DBH	+2.00	TEH	TEC		8	COLD	600UL		
119	95	0.47	104	P 2	TWD 18	DBH	-1.32	TEH	TEC		11	COLD	600UL		
119	101	0.39	113	P 2	TWD 15	DBH	-1.85	TEH	TEC		11	COLD	600UL		
120	38	0.43	115	P 2	TWD 17	DBC	+1.83	TEH	TEC		55	COLD	600UL		
120	72	0.65	76	P 2	TWD 22	09C	-1.10	TEH	TEC		5	COLD	600UL		
120	74	0.30	103	P 2	TWD 12	10H	-1.25	TEH	TEC		7	COLD	600UL		
120	80	0.33	78	P 2	TWD 13	DBH	-1.90	TEH	TEC		8	COLD	600UL		
120	86	0.25	65	P 2	TWD 9	DBH	-1.69	TEH	TEC		9	COLD	600UL		
		0.39	100	P 2	TWD 14	10H	+1.45	TEH	TEC	LOCOK	9	COLD	600UL		
120	88	0.39	65	P 2	TWD 14	03H	-0.15	TEH	TEC		9	COLD	600UL		
120	92	0.27	116	P 2	TWD 11	10H	+0.11	TEH	TEC		11	COLD	600UL		
		0.36	82	P 2	TWD 14	DBH	-2.10	TEH	TEC		11	COLD	600UL		
120	120	0.30	122	P 2	TWD 13	VH1	+0.90	TEC	TEH		1	HOT	600UL		
120	138	0.54	62	P 2	TWD 19	DBH	-1.62	TEH	TEC		20	COLD	600UL		
121	39	0.44	38	P 2	TWD 18	03C	-0.94	TEH	TEC		55	COLD	600UL		
121	41	0.52	146	P 2	TWD 19	VH1	-0.83	TEH	TEC		53	COLD	600UL		
		0.31	47	P 2	TWD 13	VH1	+0.76	TEH	TEC		53	COLD	600UL		
121	57	0.36	98	P 2	TWD 15	VH1	-1.05	TEC	TEH		8	HOT	600UL		
121	67	0.21	41	P 2	TWD 8	DBH	-1.51	TEC	TEH		4	HOT	600UL		
121	75	0.43	133	P 2	TWD 16	VH1	-0.78	TEH	TEC		8	COLD	600UL		
121	95	0.62	118	P 2	TWD 21	VH1	-0.86	TEH	TEC		12	COLD	600UL		
121	97	0.47	138	P 2	TWD 16	10H	+0.00	TEH	TEC		12	COLD	600UL		
121	99	0.57	151	P 2	TWD 19	VH1	-0.73	TEH	TEC		12	COLD	600UL		
121	125	0.26	96	P 2	TWD 12	10H	+0.70	TEC	TEH		5	HOT	600UL		
122	94	0.30	143	P 2	TWD 12	DBH	+2.22	TEH	TEC		12	COLD	600UL		
122	96	0.52	131	P 2	TWD 19	DBH	+1.85	TEH	TEC		12	COLD	600UL		
122	112	0.20	91	P 2	TWD 9	10H	-1.16	TEC	TEH		1	HOT	600UL		
122	114	0.34	84	P 2	TWD 14	10H	+0.86	TEC	TEH		1	HOT	600UL		
122	124	0.46	126	P 2	TWD 19	DBH	+1.85	TEC	TEH		5	HOT	600UL		
123	41	0.45	135	P 2	TWD 17	VH1	-0.87	TEH	TEC		53	COLD	600UL		
123	55	0.47	100	P 2	TWD 17	VH1	+0.00	TEC	TEH		7	HOT	600UL		

SG88 - MAI, MCI, MMI, MVI, SAI, SCI, SVI, 0-100%TWD

QUERY: QueryM1

ROW	LINE	VOLTS	DEG	CHN	IND	%TW	LOCATION	EXT	EXT	UTIL	1 UTIL	2 CAL #	LEG	PROBE
123	65	0.36	127	P 2	TWD	13	DBH	+0.02	TEC	TEH		3	HOT	600UL
		0.57	122	P 2	TWD	19	VH1	-0.91	TEC	TEH		3	HOT	600UL
123	67	0.44	137	P 2	TWD	15	VH1	-0.88	TEC	TEH		3	HOT	600UL
123	71	0.38	133	P 2	TWD	13	VH1	-0.84	TEH	TEC		5	COLD	600UL
123	77	0.28	102	P 2	TWD	12	VH2	-0.79	TEH	TEC		7	COLD	600UL
123	85	0.46	145	P 2	TWD	17	VH1	-0.81	TEH	TEC		8	COLD	600UL
123	97	0.50	144	P 2	TWD	17	VH1	-0.84	TEH	TEC		43	COLD	600UL
123	109	0.43	107	P 2	TWD	17	VH1	-1.07	TEC	TEH		1	HOT	600UL
123	111	0.46	67	P 2	TWD	18	DBH	+1.73	TEC	TEH		1	HOT	600UL
		0.40	91	P 2	TWD	17	VH1	-0.99	TEC	TEH		1	HOT	600UL
		0.27	106	P 2	TWD	12	10H	-0.99	TEC	TEH		1	HOT	600UL
123	115	0.37	95	P 2	TWD	15	VH1	-1.04	TEC	TEH		1	HOT	600UL
123	117	0.46	122	P 2	TWD	19	VH1	-0.96	TEC	TEH		1	HOT	600UL
123	121	0.47	94	P 2	TWD	19	VH1	-0.99	TEC	TEH		1	HOT	600UL
124	64	0.31	53	P 2	TWD	13	10H	-0.97	TEC	TEH		4	HOT	600UL
124	76	0.31	112	P 2	TWD	12	VH1	-0.79	TEH	TEC		7	COLD	600UL
125	57	0.32	81	P 2	TWD	14	VC3	+0.73	TEC	TEH		8	HOT	600UL
125	83	0.39	145	P 2	TWD	15	VH1	-0.84	TEH	TEC		8	COLD	600UL
		0.77	135	P 2	TWD	25	DBH	+2.05	TEH	TEC		8	COLD	600UL
125	85	0.42	128	P 2	TWD	16	VH1	-0.82	TEH	TEC		7	COLD	600UL
		0.25	122	P 2	TWD	11	VH2	-0.91	TEH	TEC		7	COLD	600UL
125	91	0.25	134	P 2	TWD	10	DBH	+1.83	TEH	TEC		11	COLD	600UL
125	97	0.58	131	P 2	TWD	20	VH1	-0.96	TEH	TEC		12	COLD	600UL
126	62	0.70	109	P 2	TWD	23	10H	-0.98	TEC	TEH		4	HOT	600UL
126	86	0.46	137	P 2	TWD	17	DBH	+1.94	TEH	TEC		10	COLD	600UL
126	90	0.42	122	P 2	TWD	16	DBH	+1.96	TEH	TEC		10	COLD	600UL
126	92	0.27	135	P 2	TWD	10	VH1	-0.84	TEH	TEC		12	COLD	600UL
126	112	0.37	29	P 2	TWD	16	DBH	+1.75	TEC	TEH		1	HOT	600UL
127	53	0.48	69	P 2	TWD	18	VH1	-0.92	TEC	TEH		7	HOT	600UL
127	59	0.43	106	P 2	TWD	15	VH1	-1.02	TEC	TEH		3	HOT	600UL
127	67	0.36	108	P 2	TWD	13	VH1	-0.79	TEC	TEH		3	HOT	600UL
127	75	0.42	152	P 2	TWD	16	VH1	-0.94	TEH	TEC		7	COLD	600UL
		0.25	139	P 2	TWD	11	VH1	+0.79	TEH	TEC		7	COLD	600UL
127	87	0.44	111	P 2	TWD	15	09H	-1.01	TEH	TEC		9	COLD	600UL
		0.49	127	P 2	TWD	17	10H	-1.03	TEH	TEC		9	COLD	600UL
127	95	0.33	149	P 2	TWD	14	VH1	-0.92	TEH	TEC		11	COLD	600UL
127	99	0.39	125	P 2	TWD	16	VH1	-0.87	TEH	TEC		11	COLD	600UL
127	101	0.19	103	P 2	TWD	8	VH3	+0.78	TEH	TEC		11	COLD	600UL
127	107	0.53	119	P 2	TWD	18	VH1	-0.71	TEC	TEH		2	HOT	600UL
127	109	0.27	102	P 2	TWD	12	VH1	-0.98	TEC	TEH		1	HOT	600UL
		0.56	121	P 2	TWD	21	09H	-0.99	TEC	TEH		1	HOT	600UL

SG88 - MAI, MCI, MMI, MVI, SAI, SCI, SVI, 0-100%TWD

QUERY: QueryM1

ROW	LINE	VOLTS	DEG	CHN	IND	%TW	LOCATION	EXT	EXT	UTIL	1 UTIL	2 CAL	#	LEG	PROBE
127	115	0.37	137	P 2	TWD 15	VH1	-0.93	TEC	TEH			1	HOT	600UL	
127	121	0.32	122	P 2	TWD 13	VH1	-0.99	TEC	TEH			1	HOT	600UL	
127	125	0.54	117	P 2	TWD 18	VH1	-0.86	TEC	TEH			6	HOT	600UL	
128	60	0.54	110	P 2	TWD 19	10H	-0.97	TEC	TEH			4	HOT	600UL	
128	68	0.30	27	P 2	TWD 12	DBH	+1.51	TEC	TEH			4	HOT	600UL	
128	88	0.64	108	P 2	TWD 21	10H	-1.10	TEH	TEC			9	COLD	600UL	
128	108	0.29	119	P 2	TWD 11	VH1	-0.67	TEC	TEH			2	HOT	600UL	
128	110	0.26	88	P 2	TWD 10	VH1	+0.78	TEC	TEH			2	HOT	600UL	
129	47	0.67	143	P 2	TWD 24	VH3	-0.88	TEC	TEH			8	HOT	600UL	
129	63	0.31	127	P 2	TWD 12	10H	-0.13	TEC	TEH			4	HOT	600UL	
129	67	0.33	46	P 2	TWD 13	DBH	-1.73	TEC	TEH			4	HOT	600UL	
129	73	0.46	153	P 2	TWD 18	VH1	-0.75	TEH	TEC			8	COLD	600UL	
129	75	0.57	87	P 2	TWD 20	VH1	-0.80	TEH	TEC			8	COLD	600UL	
129	87	0.41	152	P 2	TWD 15	VH1	-0.91	TEH	TEC			10	COLD	600UL	
129	95	0.50	125	P 2	TWD 17	DBH	+2.09	TEH	TEC			12	COLD	600UL	
		0.54	133	P 2	TWD 18	VH1	-0.89	TEH	TEC			12	COLD	600UL	
129	109	0.27	153	P 2	TWD 10	VH1	-0.76	TEC	TEH			2	HOT	600UL	
129	119	0.51	83	P 2	TWD 18	VH1	-0.91	TEC	TEH			2	HOT	600UL	
129	121	0.36	155	P 2	TWD 13	VH1	-0.81	TEC	TEH			2	HOT	600UL	
130	70	0.45	88	P 2	TWD 16	VH1	-0.76	TEC	TEH			3	HOT	600UL	
130	74	0.80	113	P 2	TWD 26	10H	-1.04	TEH	TEC			8	COLD	600UL	
130	94	0.48	147	P 2	TWD 16	10H	-1.00	TEH	TEC			12	COLD	600UL	
130	106	0.47	129	P 2	TWD 17	VH1	-0.79	TEH	TEC			14	COLD	600UL	
130	128	0.52	80	P 2	TWD 18	VH2	-0.54	TEC	TEH			6	HOT	600UL	
131	77	0.60	23	P 2	TWD 21	DBH	+2.00	TEH	TEC			13	COLD	600UL	
131	83	0.24	118	P 2	TWD 10	DBH	-1.85	TEH	TEC			13	COLD	600UL	
131	89	0.68	127	P 2	TWD 23	10H	+0.90	TEH	TEC			13	COLD	600UL	
131	127	0.52	126	P 2	TWD 19	03C	+0.83	TEH	TEC			17	COLD	600UL	
132	94	0.63	78	P 2	TWD 22	10H	+0.92	TEH	TEC			13	COLD	600UL	
133	61	0.39	129	P 2	TWD 15	VH1	-0.98	TEH	TEC			14	COLD	600UL	
133	75	0.49	143	P 2	TWD 18	DBH	+1.91	TEH	TEC			14	COLD	600UL	
133	83	0.41	148	P 2	TWD 15	10H	-1.02	TEH	TEC			14	COLD	600UL	
133	87	0.45	85	P 2	TWD 17	VH1	-0.97	TEH	TEC			14	COLD	600UL	
133	99	0.29	90	P 2	TWD 11	VH1	-0.89	TEH	TEC			14	COLD	600UL	
133	109	0.12	143	2	SAI	07H	-7.41	TO-9.41	07H	07H	0.40	2.00	159	HOT	580PP
		0.09	122	2	SAI	07H	-13.68	TO-15.84	07H	07H	0.40	2.16	159	HOT	580PP
		0.18	122	2	SAI	07H	-16.47	TO-22.50	07H	07H	2.00	4.90	159	HOT	580PP
133	115	0.50	128	P 2	TWD 18	10H	+0.92	TEH	TEC			17	COLD	600UL	
134	68	0.29	119	P 2	TWD 11	10H	-0.75	TEH	TEC	LAR		14	COLD	600UL	

SG88 - MAI, MCI, MMI, MVI, SAI, SCI, SVI, 0-100%TWD

QUERY: QueryM1

ROW	LINE	VOLTS	DEG	CHN	IND	%TW	LOCATION	EXT	EXT	UTIL	1 UTIL	2 CAL	#	LEG	PROBE
134	84	0.34	38	P 2	TWD	13	10H	-1.02	TEH TEC			14	COLD	600UL	
134	86	0.51	104	P 2	TWD	19	10H	-1.04	TEH TEC			13	COLD	600UL	
134	100	0.44	159	P 2	TWD	15	10H	+0.95	TEH TEC			16	COLD	600UL	
135	81	0.61	140	P 2	TWD	21	VH1	-0.83	TEH TEC			14	COLD	600UL	
135	87	0.24	161	P 2	TWD	10	10H	-0.94	TEH TEC			13	COLD	600UL	
135	93	0.30	79	P 2	TWD	12	10H	+0.88	TEH TEC			13	COLD	600UL	
135	97	0.24	120	P 2	TWD	10	10H	+0.94	TEH TEC			13	COLD	600UL	
		0.26	130	P 2	TWD	10	10H	-1.06	TEH TEC			13	COLD	600UL	
136	74	0.55	110	P 2	TWD	20	10H	-1.01	TEH TEC			13	COLD	600UL	
136	86	0.72	135	P 2	TWD	23	10H	-1.07	TEH TEC			14	COLD	600UL	
137	91	0.42	156	P 2	TWD	16	10H	-1.08	TEH TEC			14	COLD	600UL	
137	119	0.52	71	P 2	TWD	17	01C	-0.99	TEH TEC			18	COLD	600UL	
138	74	0.33	70	P 2	TWD	13	VH1	-0.75	TEH TEC			13	COLD	600UL	
138	78	0.38	94	P 2	TWD	15	VH1	-0.71	TEH TEC			13	COLD	600UL	
139	71	0.32	145	P 2	TWD	13	VH1	-0.89	TEH TEC			13	COLD	600UL	
139	105	0.49	131	P 2	TWD	17	10H	+0.88	TEH TEC			18	COLD	600UL	
140	88	0.27	147	P 2	TWD	11	DBH	+2.00	TEH TEC			13	COLD	600UL	
141	65	0.48	139	P 2	TWD	17	08C	+0.83	TEH TEC			14	COLD	600UL	
141	67	0.68	123	P 2	TWD	22	VC1	+0.85	TEH TEC			14	COLD	600UL	
141	79	0.35	145	P 2	TWD	14	VC1	+0.91	TEH TEC			13	COLD	600UL	
		0.87	75	P 2	TWD	27	DBC	+1.57	TEH TEC			13	COLD	600UL	
142	72	0.71	87	P 2	TWD	23	DBC	+1.43	TEH TEC			14	COLD	600UL	
142	82	0.76	134	P 2	TWD	24	DBC	+1.98	TEH TEC			14	COLD	600UL	
142	86	0.26	154	P 2	TWD	10	DBH	+1.88	TEH TEC			13	COLD	600UL	
142	90	0.28	129	P 2	TWD	11	DBH	+1.86	TEH TEC			13	COLD	600UL	
142	104	0.34	19	P 2	TWD	12	DBH	+1.90	TEH TEC			16	COLD	600UL	
142	110	0.54	54	P 2	TWD	18	DBH	+1.97	TEH TEC			18	COLD	600UL	
143	73	0.19	64	P 2	TWD	8	01H	-0.89	TEH TEC			13	COLD	600UL	
143	87	0.43	121	2	SAI	06H		+0.48	06H 06H	0.00	0.23	166	HOT	580PP	
143	89	0.24	49	P 2	TWD	10	DBH	-1.90	TEH TEC			13	COLD	600UL	
143	109	0.30	136	P 2	TWD	10	DBH	-1.51	TEH TEC			18	COLD	600UL	
144	74	0.57	106	P 2	TWD	20	VC1	+0.90	TEH TEC			14	COLD	600UL	
144	78	0.41	141	P 2	TWD	15	DBC	-1.58	TEH TEC			14	COLD	600UL	
144	80	0.40	138	P 2	TWD	16	DBH	+1.99	TEH TEC			13	COLD	600UL	
144	82	0.75	88	P 2	TWD	25	DBC	+1.48	TEH TEC			13	COLD	600UL	
144	84	0.61	102	P 2	TWD	21	DBC	+1.31	TEH TEC			13	COLD	600UL	
144	86	0.30	147	P 2	TWD	12	DBH	+1.90	TEH TEC			13	COLD	600UL	
144	88	0.86	37	P 2	TWD	27	DBC	+1.38	TEH TEC			13	COLD	600UL	
144	90	0.78	57	P 2	TWD	24	DBC	+1.27	TEH TEC			14	COLD	600UL	

SG88 - MAI, MCI, MMI, MVI, SAI, SCI, SVI, 0-100%TWD

QUERY: QueryM1

ROW	LINE	VOLTS	DEG	CHN	IND	%TW	LOCATION	EXT	EXT	UTIL	1	UTIL	2	CAL	#	LEG	PROBE
144	96	0.34	139	P 2	TWD	14	DBH	+2.16	TEH TEC			13	COLD		600UL		
144	106	1.01	91	P 2	TWD	28	DBC	+1.84	TEH TEC			18	COLD		600UL		
145	73	0.44	130	P 2	TWD	16	10H	-1.12	TEH TEC			14	COLD		600UL		
	1.01	106	P 2	TWD	29	DBH	+1.72	TEH TEC			14	COLD		600UL			
	0.63	133	P 2	TWD	21	VC1	+0.92	TEH TEC			14	COLD		600UL			
	1.32	18	P 2	TWD	33	DBC	+1.57	TEH TEC			14	COLD		600UL			
145	75	0.74	88	P 2	TWD	23	DBH	+1.89	TEH TEC			14	COLD		600UL		
	0.44	139	P 2	TWD	16	VH1	-0.89	TEH TEC			14	COLD		600UL			
145	79	0.39	147	P 2	TWD	14	DBC	+1.25	TEH TEC			14	COLD		600UL		
145	81	0.49	146	P 2	TWD	18	VH1	-0.85	TEH TEC			13	COLD		600UL		
	0.81	84	P 2	TWD	26	DBC	-1.32	TEH TEC			13	COLD		600UL			
145	83	0.32	147	P 2	TWD	12	DBH	-1.74	TEH TEC			14	COLD		600UL		
	0.48	80	P 2	TWD	17	VC1	+0.91	TEH TEC			14	COLD		600UL			
145	89	0.48	94	P 2	TWD	17	VC1	+0.83	TEH TEC			14	COLD		600UL		
	0.29	106	P 2	TWD	11	DBH	-1.72	TEH TEC			14	COLD		600UL			
145	91	1.13	21	P 2	TWD	30	DBC	+1.51	TEH TEC			14	COLD		600UL		
	0.43	138	P 2	TWD	16	VH2	+0.71	TEH TEC			14	COLD		600UL			
146	100	0.82	145	P 2	TWD	24	DBH	-1.85	TEH TEC			16	COLD		600UL		
147	85	0.79	96	P 2	TWD	25	DBC	+1.52	TEH TEC			14	COLD		600UL		
	0.72	139	P 2	TWD	23	VC1	-0.83	TEH TEC			14	COLD		600UL			
	0.40	140	P 2	TWD	15	DBH	-2.04	TEH TEC			14	COLD		600UL			
	0.36	56	P 2	TWD	14	VH1	+0.79	TEH TEC			14	COLD		600UL			
	0.80	111	P 2	TWD	25	VC1	+0.14	TEH TEC			14	COLD		600UL			
	1.23	130	P 2	TWD	32	VC1	+0.83	TEH TEC			14	COLD		600UL			
147	89	0.36	121	P 2	TWD	14	VC2	+0.81	TEH TEC			14	COLD		600UL		
	1.29	131	P 2	TWD	32	VC1	+0.79	TEH TEC			14	COLD		600UL			
147	91	0.58	145	P 2	TWD	20	VC1	-0.82	TEH TEC			14	COLD		600UL		
147	93	0.22	147	P 2	TWD	9	DBH	-1.75	TEH TEC			14	COLD		600UL		
	1.05	116	P 2	TWD	29	VC1	+0.90	TEH TEC			14	COLD		600UL			
	0.38	123	P 2	TWD	14	VC1	-0.54	TEH TEC			14	COLD		600UL			
	0.29	106	P 2	TWD	11	DBC	-1.57	TEH TEC			14	COLD		600UL			

Total Tubes : 465
Total Records: 556

Appendix 4
Inspection Summary
Steam Generator E-089

SG89 - MAI, MCI, MMI, MVI, SAI, SCI, SVI, 0-100%TWD

QUERY: QueryM1

ROW	LINE	VOLTS	DEG	CHN	IND	%TW	LOCATION	EXT	EXT	UTIL	1 UTIL	2	CAL #	LEG	PROBE
1	175	0.22	19	P 2	TWD 10	DBH	+1.25	DBH	TEH	LAR		14	HOT	600UL	
2	154	0.23	107	2	SVI	TSH	+7.15	TO+7.39	TSH	TSH	0.39	0.35	133	HOT	580PP
2	158	0.17	111	2	SVI	TSH	+5.77	TO+5.92	TSH	TSH	0.31	0.29	133	HOT	580PP
4	120	0.43	79	2	SAI	07H	-0.02		07H	DBH	0.71	0.18	130	HOT	580PP
6	60	0.37	48	P 2	TWD 17	02H	-1.35	TEC	TEH	LOCOK		19	HOT	600UL	
7	175	0.31	56	P 2	TWD 16	02C	+0.83	TEH	TEC			24	COLD	600UL	
9	33	.1.25	13	2	SAI	06H	+0.51	06H	06H	0.00	0.35	123	HOT	580PP	
9	39	-0.41	65	P 2	TWD 18	03H	+0.85	TEH	TEC			46	COLD	600UL	
10	52	0.34	90	P 2	TWD 16	01C	+0.23	TEC	TEH			9	HOT	600UL	
11	119	0.30	65	P 2	TWD 13	07H	+0.87	TEC	TEH			24	HOT	600UL	
11	141	0.56	26	P 1	SCI	TSH	-0.08	TSH	TSH	0.64	0.16	43	HOT	600PP	
13	119	0.24	92	2	SAI	06H	-0.18	06H	06H	0.30	0.18	129	HOT	580PP	
13	139	0.33	19	P 1	SCI	TSH	-4.91	TSH	TSH	0.19	0.19	39	HOT	600PP	
14	116	0.36	87	P 2	TWD 14	07H	-0.23	TEC	TEH			23	HOT	600UL	
14	174	0.11	86	2	SAI	03H	-1.25	03H	03H	0.00	0.28	137	HOT	580PP	
16	42	0.25	17	P 1	SCI	TSH	-0.07	TSH	TSH	0.13	0.20	61	HOT	600PP	
16	58	0.42	96	P 2	TWD 17	07H	-0.16	TEC	TEH			22	HOT	600UL	
18	16	0.21	136	2	SAI	06H	+0.36	06H	06H	0.35	0.25	117	HOT	580PP	
19	121	0.23	110	2	SAI	04H	-0.51	04H	04H	0.67	0.20	129	HOT	580PP	
19	173	0.11	146	P 2	TWD 6	VSM	+0.81	TEH	TEC			24	COLD	600UL	
20	58	0.46	128	P 2	TWD 19	01H	+0.93	TEC	TEH			22	HOT	600UL	
21	113	0.30	130	P 2	TWD 13	07C	+0.80	STH	TEC			41	COLD	600UL	
22	2	0.54	139	P 2	TWD 21	VSM	-0.89	TEH	TEC			46	COLD	600UL	
22	60	0.73	16	2	SAI	TSH	-1.48	TSH	TSH	0.87	0.16	77	HOT	600PP	
22	66	0.47	16	2	SAI	TSH	-2.22	TSH	TSH	0.49	0.16	82	HOT	600PP	
22	126	0.15	108	2	SAI	02H	+5.14	02H	02H	0.12	0.22	129	HOT	580PP	
23	169	0.42	67	P 2	TWD 18	02H	+0.88	TEH	TEC			25	COLD	600UL	
24	48	0.79	26	P 1	SCI	TSH	-0.09	TSH	TSH	0.98	0.21	86	HOT	580PP	
24	54	0.23	116	P 1	SCI	TSH	+0.16	TSH	TSH	0.36	0.29	81	HOT	600PP	
24	112	0.17	131	P 1	MCI	TSH	+0.00	TO+0.12	TSH	TSH	0.17	0.17	60	HOT	600PP
25	115	0.19	125	P 1	SCI	TSH	+0.14	TO+0.31	TSH	TSH	0.35	0.17	60	HOT	600PP
26	118	0.21	93	P 1	MCI	TSH	+0.12	TSH	TSH	0.25	0.24	63	HOT	600PP	
28	118	0.11	99	P 1	SCI	TSH	+0.12	TSH	TSH	0.29	0.31	64	HOT	600PP	
29	49	0.20	77	P 1	SCI	TSH	+0.04	TSH	TSH	0.30	0.19	86	HOT	580PP	
29	115	0.56	18	2	SAI	TSH	-0.80	TO-0.89	TSH	TSH	0.58	0.45	60	HOT	600PP
30	54	0.14	105	P 1	MCI	TSH	+0.12	TSH	TSH	0.36	0.24	81	HOT	600PP	
30	108	0.25	20	P 2	TWD 13	06C	-0.86	TEC	TEH			30	HOT	600UL	
31	65	0.18	106	2	SAI	TSH	+1.09	TSH	TSH	0.00	0.15	94	HOT	580PP	

SG89 - MAI, MCI, MMI, MVI, SAI, SCI, SVI, 0-100%TWD

QUERY: QueryM1

ROW	LINE	VOLTS	DEG	CHN	IND	%TW	LOCATION	EXT	EXT	UTIL	1	UTIL	2	CAL	#	LEG	PROBE
31	71	0.54	77	P 2	TWD 22	DBH	-1.73	TEH	TEC		23	COLD	600UL				
		0.29	147	P 2	TWD 14	DBC	-1.73	TEH	TEC		23	COLD	600UL				
		0.26	111	P 2	TWD 13	DBC	+1.79	TEH	TEC		23	COLD	600UL				
31	117	0.31	142	P 2	TWD 13	07C	+0.41	TEC	TEH		24	HOT	600UL				
34	54	0.86	13	2	SAI	07H	-0.13	07H	07H	0.00	0.16	138	HOT	580PP			
35	105	0.72	23	2	SAI	TEH	+1.89	TEH	TEH	1.16	0.20	116	HOT	580PP			
		2.04	29	2	SAI	TEH	+3.69	TEH	TEH	3.53	0.41	116	HOT	580PP			
		1.44	22	2	SAI	TEH	+4.67	TEH	TEH	1.74	0.35	116	HOT	580PP			
		1.33	26	2	SAI	TEH	+4.92	TEH	TEH	1.26	0.17	116	HOT	580PP			
		2.17	30	2	SAI	TEH	+5.56	TEH	TEH	3.04	0.47	116	HOT	580PP			
		-2.73	26	2	SAI	TSH	-6.79	TSH	TSH	2.33	0.34	158	HOT	580PP			
		3.87	32	2	MAI	TSH	-9.43	TSH	TSH	5.98	0.92	158	HOT	580PP			
37	75	0.72	104	P 2	TWD 25	DBC	-1.27	TEC	TEH		33	HOT	600UL				
		0.45	130	P 2	TWD 19	DBC	+1.70	TEC	TEH		33	HOT	600UL				
37	107	0.40	16	2	SAI	TSH	-5.75	TO-5.83	TSH	TSH	0.28	0.34	60	HOT	600PP		
38	4	0.37	65	P 2	TWD 16	02C	-0.94	TEH	TEC		51	COLD	600UL				
		0.35	56	P 2	TWD 15	01C	+0.06	TEH	TEC		51	COLD	600UL				
38	52	0.13	130	2	SAI	02H	+6.61	02H	02H	0.39	0.62	135	HOT	580PP			
38	66	0.33	155	P 2	TWD 14	VSM	-0.72	TEC	TEH		15	HOT	600UL				
38	102	1.15	75	P 2	TWD 34	DBH	-1.75	TEC	TEH		40	HOT	600UL				
		0.28	52	P 2	TWD 13	DBH	+1.69	TEC	TEH		40	HOT	600UL				
38	164	0.28	109	2	SAI	06H	+0.20	06H	06H	0.52	0.15	136	HOT	580PP			
38	166	0.40	69	P 2	TWD 17	VSM	-0.82	TEH	TEC		25	COLD	600UL				
39	37	0.51	22	P 1	SCI	TSH	-0.04	TSH	TSH	0.17	0.20	61	HOT	600PP			
39	53	0.34	96	2	SAI	TSH	+0.87	TSH	TSH	0.50	0.27	85	HOT	580PP			
39	73	0.66	118	P 2	TWD 25	DBC	-1.85	TEH	TEC		23	COLD	600UL				
40	62	0.32	28	P 2	TWD 14	DBC	-0.10	TEC	TEH		15	HOT	600UL				
41	73	0.11	15	P 2	TWD 7	DBC	-2.14	TEH	TEC		21	COLD	600UL				
41	75	0.49	74	P 2	TWD 19	DBC	+1.54	TEC	TEH		33	HOT	600UL				
41	103	0.40	16	2	SAI	TSH	-0.68	TSH	TSH	0.60	0.15	103	HOT	580PP			
		0.29	142	P 2	TWD 13	VSM	+0.80	TEC	TEH		40	HOT	600UL				
41	159	0.34	78	P 2	TWD 14	01H	+1.16	TEH	TEC		27	COLD	600UL				
42	110	0.67	74	P 2	TWD 23	VSM	-0.24	TEC	TEH		31	HOT	600UL				
		0.87	116	P 2	TWD 27	VSM	+0.93	TEC	TEH		31	HOT	600UL				
42	168	0.53	148	P 2	TWD 23	VSM	+1.06	TEH	TEC		24	COLD	600UL				
42	170	0.74	92	P 2	TWD 28	VSM	-0.30	TEH	TEC		24	COLD	600UL				
43	79	0.81	74	P 2	TWD 25	DBH	+1.74	TEC	TEH		32	HOT	600UL				
43	101	0.72	65	P 2	TWD 26	DBC	+1.74	TEC	TEH		40	HOT	600UL				
44	18	0.35	150	P 2	TWD 16	VSM	-0.83	TEH	TEC		54	COLD	600UL				
		0.18	53	P 2	TWD 9	VSM	+0.65	TEH	TEC	LAR	54	COLD	600UL				
44	54	0.16	81	2	SAI	TSH	+1.33	TSH	TSH	0.40	0.14	90	HOT	580PP			
44	74	0.44	86	P 2	TWD 17	DBC	-1.70	TEC	TEH		33	HOT	600UL				
		0.27	7	P 2	TWD 12	DBC	+1.94	TEC	TEH	LAR	33	HOT	600UL				
44	100	1.13	107	P 2	TWD 27	DBC	+1.67	TEC	TEH		41	HOT	600UL				
44	108	0.94	119	P 2	TWD 32	VSM	-0.87	TEC	TEH		30	HOT	600UL				

SG89 - MAI, MCI, MMI, MVI, SAI, SCI, SVI, 0-100%TWD

QUERY: QueryM1

ROW	LINE	VOLTS	DEG	CHN	IND	%TW	LOCATION	EXT	EXT	UTIL	1	UTIL	2	CAL	#	LEG	PROBE
44	112	0.45	143	P 2	TWD 23	VSM	-0.86	TEH	TEH		28	HOT				600UL	
45	73	0.20	133	P 2	TWD 11	DBC	-2.03	TEH	TEC		21	COLD				600UL	
45	99	0.57	46	P 2	TWD 23	DBC	+1.82	TEC	TEH		40	HOT				600UL	
		0.96	71	P 2	TWD 31	DBH	-1.90	TEC	TEH		40	HOT				600UL	
		0.89	57	P 2	TWD 30	DBC	-1.75	TEC	TEH		40	HOT				600UL	
45	103	0.43	120	P 2	TWD 18	VSM	+0.97	TEC	TEH		40	HOT				600UL	
45	145	0.28	55	P 2	TWD 12	VSM	-0.75	TEH	TEC		33	COLD				600UL	
45	167	0.51	54	P 2	TWD 22	VSM	+0.89	TEH	TEC		24	COLD				600UL	
46	104	0.69	136	P 2	TWD 26	VSM	-0.84	TEC	TEH		40	HOT				600UL	
		0.41	154	P 2	TWD 18	VSM	+0.25	TEC	TEH		40	HOT				600UL	
46	128	0.30	115	P 2	TWD 18	VSM	-0.93	TEC	TEH		17	HOT				600UL	
46	156	0.41	122	P 2	TWD 18	VSM	-0.87	TEH	TEC		29	COLD				600UL	
		0.22	144	P 2	TWD 11	VSM	+0.91	TEH	TEC		29	COLD				600UL	
46	162	0.29	103	P 2	TWD 13	VSM	+0.87	TEH	TEC		26	COLD				600UL	
47	33	0.46	39	P 2	TWD 17	DBH	+1.89	TEH	TEC		48	COLD				600UL	
47	45	1.69	23	2	SAI	TSH	-5.84	TSH	TSH	1.72	0.35	65	HOT			600PP	
47	49	0.41	136	P 1	MCI	TSH	-0.00	TSH	TSH	0.43	0.53	85	HOT			580PP	
47	101	0.67	95	P 2	TWD 25	DBC	+1.75	TEC	TEH		40	HOT				600UL	
47	121	0.26	147	P 2	TWD 8	VSM	-0.97	TEC	TEH		23	HOT				600UL	
48	6	0.60	104	P 2	TWD 23	08C	-1.85	TEH	TEC	LOCOK	51	COLD				600UL	
48	8	0.24	110	P 2	TWD 12	02C	+0.86	TEH	TEC		51	COLD				600UL	
48	34	0.27	33	P 2	TWD 12	VSM	-0.59	TEH	TEC		47	COLD				600UL	
48	66	0.76	157	P 2	TWD 24	VSM	-0.93	TEC	TEH		16	HOT				600UL	
48	98	0.73	137	P 2	TWD 20	DBH	+1.85	TEC	TEH		41	HOT				600UL	
		1.55	119	P 2	TWD 33	DBH	+0.00	TEC	TEH	LAR	41	HOT				600UL	
48	100	0.46	140	P 2	TWD 14	DBC	+1.77	TEC	TEH		41	HOT				600UL	
48	118	0.47	116	P 2	TWD 23	04H	-1.04	TEC	TEH	LAR	28	HOT				600UL	
49	49	0.31	59	P 2	TWD 14	08H	+1.49	TEC	TEH	LOCOK	19	HOT				600UL	
49	55	0.29	120	P 2	TWD 11	VSM	-0.70	TEH	TEC		62	COLD				580SF	
49	65	0.42	119	P 2	TWD 16	VSM	-0.74	TEC	TEH		16	HOT				600UL	
49	99	0.89	120	P 2	TWD 23	DBC	-1.56	TEC	TEH		41	HOT				600UL	
		0.55	110	P 2	TWD 16	DBH	-1.79	TEC	TEH		41	HOT				600UL	
49	109	0.38	113	P 2	TWD 15	08H	-1.06	TEC	TEH		31	HOT				600UL	
49	111	0.54	71	P 2	TWD 24	08H	-1.27	TEC	TEH	LOCOK	30	HOT				600UL	
49	113	0.42	44	P 2	TWD 17	08H	-0.99	STH	TEC		43	COLD				600UL	
49	145	0.66	36	P 2	TWD 24	08H	-1.07	TEH	TEC		33	COLD				600UL	
50	44	0.39	122	P 2	TWD 16	VSM	-0.83	TEH	TEC		4	COLD				600UL	
50	52	0.17	130	P 1	SCI	TSH	-0.00	TSH	TSH	0.00	0.26	86	HOT			580PP	
50	58	0.42	101	P 2	TWD 17	02H	-1.19	TEC	TEH		22	HOT				600UL	
50	64	0.44	59	P 2	TWD 17	08H	+1.02	TEC	TEH		16	HOT				600UL	

SG89 - MAI, MCI, MMI, MVI, SAI, SCI, SVI, 0-100%TWD

QUERY: QueryM1

ROW	LINE	VOLTS	DEG	CHN	IND	%TW	LOCATION	EXT	EXT	UTIL	1	UTIL	2	CAL	#	LEG	PROBE
50	74	0.38	105	P 2	TWD 16	DBC	+1.54	TEC	TEH		33	HOT		600UL			
		0.26	142	P 2	TWD 11	DBC	-1.70	TEC	TEH		33	HOT		600UL			
50	76	0.45	103	P 2	TWD 18	DBC	-1.72	TEC	TEH		33	HOT		600UL			
50	82	0.72	71	P 2	TWD 23	DBC	+1.79	TEC	TEH		32	HOT		600UL			
		0.30	114	P 2	TWD 11	DBH	-1.73	TEC	TEH		32	HOT		600UL			
		0.29	152	P 2	TWD 12	DBC	-1.89	TEC	TEH		32	HOT		600UL			
50	98	1.14	133	P 2	TWD 34	DBH	-1.67	TEC	TEH		40	HOT		600UL			
50	100	0.38	86	P 2	TWD 17	01H	+0.93	TEC	TEH		40	HOT		600UL			
51	61	0.40	155	P 2	TWD 18	08C	-0.73	TEC	TEH		21	HOT		600UL			
51	75	0.54	115	P 2	TWD 20	DBC	-1.80	STH	TEC		42	COLD		600UL			
51	95	0.40	76	P 2	TWD 18	DBC	+1.80	TEC	TEH		40	HOT		600UL			
51	97	0.86	58	P 2	TWD 29	DBC	-2.00	TEC	TEH		40	HOT		600UL			
		0.41	61	P 2	TWD 18	DBH	-2.00	TEC	TEH		40	HOT		600UL			
51	99	1.02	97	P 2	TWD 32	DBC	-2.00	TEC	TEH		40	HOT		600UL			
		0.56	116	P 2	TWD 22	VSM	+0.84	TEC	TEH		40	HOT		600UL			
		0.30	68	P 2	TWD 14	VH3	+0.78	TEC	TEH		40	HOT		600UL			
		0.40	29	P 2	TWD 18	VC3	+0.82	TEC	TEH		40	HOT		600UL			
		0.13	78	P 2	TWD 6	VC3	-0.60	TEC	TEH		40	HOT		600UL			
52	18	0.45	135	P 2	TWD 19	VH3	-1.04	TEH	TEC		54	COLD		600UL			
52	76	0.34	61	P 2	TWD 13	DBC	-1.50	TEC	TEH		32	HOT		600UL			
52	80	0.47	79	P 2	TWD 17	DBC	-2.00	TEC	TEH		32	HOT		600UL			
52	84	0.27	42	P 2	TWD 10	DBH	-1.76	TEC	TEH		32	HOT		600UL			
52	92	0.76	146	P 2	TWD 20	DBC	+1.86	TEC	TEH		41	HOT		600UL			
		1.41	109	P 2	TWD 31	DBH	-1.64	TEC	TEH		41	HOT		600UL			
		0.44	109	P 2	TWD 13	DBH	+1.43	TEC	TEH		41	HOT		600UL			
52	96	0.39	151	P 2	TWD 12	DBH	-1.40	TEC	TEH		41	HOT		600UL			
53	77	0.39	106	P 2	TWD 14	DBC	-1.80	TEC	TEH		32	HOT		600UL			
53	83	0.87	82	P 2	TWD 26	DBC	-1.82	TEC	TEH		32	HOT		600UL			
		0.35	58	P 2	TWD 13	DBH	+1.71	TEC	TEH		32	HOT		600UL			
53	141	0.34	84	P 2	TWD 14	VC3	+0.83	TEH	TEC		33	COLD		600UL			
54	82	1.18	81	P 2	TWD 33	DBC	+1.71	TEC	TEH		33	HOT		600UL			
54	92	0.63	131	P 2	TWD 24	DBC	+1.88	TEC	TEH		40	HOT		600UL			
		1.43	88	P 2	TWD 37	DBH	-1.61	TEC	TEH		40	HOT		600UL			
54	94	0.94	124	P 2	TWD 24	DBH	-1.32	TEC	TEH		41	HOT		600UL			
54	128	0.30	60	P 2	TWD 18	02H	-1.24	TEC	TEH		17	HOT		600UL			
55	69	0.17	107	2	SAI	TSH	+0.85	TSH	TSH	0.00	0.15	94	HOT		580PP		
55	81	1.07	120	P 2	TWD 31	DBC	-1.65	TEC	TEH		33	HOT		600UL			
55	83	1.24	106	P 2	TWD 34	DBC	-1.74	TEC	TEH		33	HOT		600UL			
55	95	1.42	73	P 2	TWD 37	DBC	+1.93	TEC	TEH		40	HOT		600UL			
55	151	0.40	67	P 2	TWD 18	VH3	+0.85	TEH	TEC		31	COLD		600UL			
56	34	0.38	35	P 2	TWD 17	VC3	+0.80	TEH	TEC		47	COLD		600UL			
		0.42	122	P 2	TWD 18	VH3	-0.65	TEH	TEC		47	COLD		600UL			
		0.38	57	P 2	TWD 16	VH3	+0.76	TEH	TEC		47	COLD		600UL			
56	64	0.23	120	P 2	TWD 11	VH3	-0.96	TEC	TEH		15	HOT		600UL			
56	82	0.39	50	P 2	TWD 15	VH3	+0.80	TEC	TEH		32	HOT		600UL			

SG89 - MAI, MCI, MMI, MVI, SAI, SCI, SVI, 0-100%TWD

QUERY: QueryM1

ROW	LINE	VOLTS	DEG	CHN	IND	%TW	LOCATION	EXT	EXT	UTIL	1 UTIL	2	CAL #	LEG	PROBE
		0.85	92	P 2	TWD 26	VH3	-0.76	TEC	TEH			32	HOT	600UL	
56	84	0.57	141	P 2	TWD 21	DBC	-1.80	STH	TEC			42	COLD	600UL	
		0.44	104	P 2	TWD 17	DBH	+1.82	STH	TEC			42	COLD	600UL	
56	88	1.29	116	P 2	TWD 34	DBH	+1.75	TEC	TEH			33	HOT	600UL	
56	90	0.36	113	P 2	TWD 14	DBC	+1.61	TEC	TEH			37	HOT	600UL	
		1.43	66	P 2	TWD 35	DBH	-1.24	TEC	TEH			37	HOT	600UL	
		0.29	150	P 2	TWD 11	DBH	+1.41	TEC	TEH			37	HOT	600UL	
56	94	0.65	60	P 2	TWD 25	DBH	-1.75	TEC	TEH			40	HOT	600UL	
56	104	0.50	159	P 2	TWD 17	DBC	-0.47	TEC	TEH			41	HOT	600UL	
56	108	0.32	58	P 2	TWD 13	VSM	+0.65	TEC	TEH			31	HOT	600UL	
56	146	0.52	25	P 2	TWD 20	VH3	-0.68	TEH	TEC			30	COLD	600UL	
56	152	0.35	78	P 2	TWD 16	DBH	+1.02	TEH	TEC			29	COLD	600UL	
56	158	0.48	87	P 2	TWD 21	VH3	-0.63	TEH	TEC			29	COLD	600UL	
56	162	0.66	99	P 2	TWD 24	VH3	-0.85	TEH	TEC			27	COLD	600UL	
57	69	0.14	113	2	MAI	TSH	+2.02	TO+2.96	TSH	TSH	0.24	0.21	93	HOT	580PP
57	79	0.54	84	P 2	TWD 19	DBC	-1.90	TEC	TEH			32	HOT	600UL	
57	81	0.13	105	2	SAI	TSH	+1.22	TSH	TSH	0.00	0.22	98	HOT	580PP	
57	83	0.98	72	P 2	TWD 28	DBC	-1.82	TEC	TEH			32	HOT	600UL	
57	105	0.27	18	P 1	SCI	TSH	-0.12	TSH	TSH	0.40	0.19	102	HOT	580PP	
58	16	0.55	127	P 2	TWD 22	VH3	-0.71	TEH	TEC			54	COLD	600UL	
58	82	0.35	106	P 2	TWD 15	DBH	+1.54	TEC	TEH			33	HOT	600UL	
58	88	1.49	112	P 2	TWD 36	DBH	+1.72	TEC	TEH			32	HOT	600UL	
58	90	0.77	73	P 2	TWD 28	DBH	-1.83	TEC	TEH			36	HOT	600UL	
59	25	0.56	135	P 2	TWD 24	VH3	-0.73	TEH	TEC			50	COLD	600UL	
59	99	0.26	103	P 1	SCI	TSH	+0.12	TSH	TSH	0.00	0.36	102	HOT	580PP	
59	143	0.25	149	P 2	TWD 12	VH3	-0.71	TEH	TEC			33	COLD	600UL	
60	88	0.69	146	P 2	TWD 22	DBH	+1.40	TEC	TEH			32	HOT	600UL	
60	94	0.37	134	P 2	TWD 16	DBC	-2.02	TEC	TEH			40	HOT	600UL	
61	87	0.53	83	P 1	SCI	TSH	+0.04	TSH	TSH	0.53	0.90	98	HOT	580PP	
61	93	0.27	132	P 1	SCI	TSH	+0.05	TSH	TSH	0.00	0.19	106	HOT	580PP	
62	84	0.43	151	P 2	TWD 17	DBC	-1.93	TEC	TEH			33	HOT	600UL	
		0.71	122	P 2	TWD 24	DBH	-1.81	TEC	TEH			33	HOT	600UL	
62	90	0.21	137	P 1	SCI	TSH	+0.11	TSH	TSH	0.25	0.16	102	HOT	580PP	
62	94	0.69	147	P 2	TWD 19	DBC	+1.90	TEC	TEH			41	HOT	600UL	
62	126	0.22	78	P 2	TWD 10	VH3	+0.77	TEC	TEH			18	HOT	600UL	
63	35	0.25	150	P 2	TWD 10	VH3	-0.54	TEH	TEC			48	COLD	600UL	
63	45	0.34	66	P 2	TWD 15	VSM	-0.76	TEH	TEC			4	COLD	600UL	
63	61	0.41	50	P 2	TWD 17	03H	-0.95	TEC	TEH			22	HOT	600UL	
63	79	0.82	86	P 2	TWD 27	DBC	-1.86	TEC	TEH			33	HOT	600UL	
63	83	0.78	149	P 2	TWD 26	DBC	-1.93	TEC	TEH			33	HOT	600UL	

SG89 - MAI, MCI, MMI, MVI, SAI, SCI, SVI, 0-100%TWD

QUERY: QueryM1

ROW	LINE	VOLTS	DEG	CHN	IND	%TW	LOCATION	EXT	EXT	UTIL	1 UTIL	2	CAL #	LEG	PROBE
63	87	0.68	128	P 2	TWD 24	DBH	-1.60	STH	TEC		42	COLD	600UL		
63	91	0.28	24	2	SAI	TSH	-0.97	TSH	TSH	0.71	0.23	102	HOT	580PP	
63	145	0.43	57	P 2	TWD 16	VH3	+0.85	TEH	TEC		30	COLD	600UL		
64	10	0.52	137	P 2	TWD 21	03C	-0.97	TEH	TEC		51	COLD	600UL		
64	82	0.65	115	P 2	TWD 23	DBC	+1.89	TEC	TEH		33	HOT	600UL		
64	84	0.41	102	P 2	TWD 15	DBH	+1.87	TEC	TEH		32	HOT	600UL		
64	136	0.31	140	P 2	TWD 15	VC3	-1.16	TEH	TEC		35	COLD	600UL		
65	37	0.41	89	P 2	TWD 19	VSM	-0.70	TEH	TEC		45	COLD	600UL		
65	79	0.18	87	2	SAI	TSH	+1.80	TSH	TSH	0.00	0.19	98	HOT	580PP	
		0.39	146	P 2	TWD 15	DBC	-1.50	TEC	TEH		32	HOT	600UL		
65	81	0.24	114	2	MAI	TSH	+0.65	TSH	TSH	0.39	0.36	98	HOT	580PP	
65	89	0.66	113	P 2	TWD 26	DBH	+1.83	TEC	TEH		36	HOT	600UL		
65	155	0.42	70	P 2	TWD 17	VH3	-0.72	TEH	TEC		28	COLD	600UL		
66	80	0.23	65	P 2	TWD 9	DBC	+1.90	TEC	TEH		32	HOT	600UL		
66	84	0.45	32	P 2	TWD 18	DBH	-1.89	TEC	TEH		33	HOT	600UL		
66	94	0.45	44	P 2	TWD 19	DBC	+1.75	TEC	TEH		40	HOT	600UL		
66	138	0.31	113	P 2	TWD 16	08C	-0.97	TEH	TEC		34	COLD	600UL		
66	144	0.46	72	P 2	TWD 21	VH3	-0.94	TEH	TEC		32	COLD	600UL		
		0.52	100	P 2	TWD 23	VSM	-0.85	TEH	TEC		32	COLD	600UL		
		0.58	77	P 2	TWD 25	06C	-0.87	TEH	TEC		32	COLD	600UL		
67	31	0.82	89	2	SAI	04H	+0.59	04H	04H	0.75	0.38	122	HOT	580PP	
67	83	0.23	132	P 2	TWD 11	DBH	-1.97	TEC	TEH		33	HOT	600UL		
		0.70	128	P 2	TWD 24	DBC	-1.95	TEC	TEH		33	HOT	600UL		
68	84	0.18	25	P 2	TWD 7	VSM	-0.75	TEC	TEH		32	HOT	600UL		
68	90	0.70	113	P 2	TWD 26	DBC	-1.97	TEC	TEH		36	HOT	600UL		
68	112	0.11	115	2	SAI	01H	+6.27	01H	01H	0.20	0.30	124	HOT	580PP	
68	128	0.36	71	P 2	TWD 16	VH3	-0.79	TEC	TEH		18	HOT	600UL		
68	162	0.48	114	P 2	TWD 19	VH3	-0.78	TEH	TEC		27	COLD	600UL		
69	151	0.37	55	P 2	TWD 15	VH3	-0.74	TEH	TEC		30	COLD	600UL		
		0.31	43	P 2	TWD 13	VH3	+0.89	TEH	TEC		30	COLD	600UL		
70	38	0.40	117	P 2	TWD 17	VC3	+0.70	TEH	TEC		4	COLD	600UL		
70	66	0.38	23	P 1	SCI	TSH	+0.07	TSH	TSH	0.15	0.21	90	HOT	580PP	
70	76	0.39	77	P 2	TWD 16	VSM	+1.00	TEC	TEH		33	HOT	600UL		
70	112	0.53	133	P 2	TWD 19	03C	-0.06	TEC	TEH		29	HOT	600UL		
70	144	0.38	119	P 2	TWD 18	VC3	-0.75	TEH	TEC		32	COLD	600UL		
70	152	0.35	105	P 2	TWD 13	VH3	-0.92	TEH	TEC		30	COLD	600UL		
71	63	0.30	18	P 1	SCI	TSH	-0.18	TSH	TSH	0.00	0.17	90	HOT	580PP	
71	79	0.53	147	P 2	TWD 20	DBC	-1.66	TEC	TEH		33	HOT	600UL		
71	91	0.26	144	P 2	TWD 13	DBC	-2.10	TEC	TEH		36	HOT	600UL		
71	97	1.02	62	P 2	TWD 33	VSM	-0.02	TEC	TEH		36	HOT	600UL		

SG89 - MAI, MCI, MMI, MVI, SAI, SCI, SVI, 0-100%TWD

QUERY: QueryM1

ROW	LINE	VOLTS	DEG	CHN	IND	%TW	LOCATION	EXT	EXT	UTIL	1 UTIL	2	CAL #	LEG	PROBE
71	143	0.46	113	P 2	TWD	18	VH3	-0.82	TEH	TEC		33	COLD	600UL	
		0.31	91	P 2	TWD	13	04C	-0.20	TEH	TEC		33	COLD	600UL	
71	147	0.74	102	P 2	TWD	28	VH3	-0.84	TEH	TEC		31	COLD	600UL	
		0.45	117	P 2	TWD	20	VC3	-0.84	TEH	TEC		31	COLD	600UL	
72	26	0.60	147	P 2	TWD	26	VC3	+0.89	TEH	TEC		50	COLD	600UL	
72	78	0.21	145	P 2	TWD	9	VH3	+0.83	TEC	TEH		32	HOT	600UL	
		0.18	152	P 2	TWD	7	VC3	+0.83	TEC	TEH		32	HOT	600UL	
		0.48	71	P 2	TWD	17	VH3	-0.89	TEC	TEH		32	HOT	600UL	
72	80	0.31	110	P 2	TWD	12	VC3	+0.97	TEC	TEH		32	HOT	600UL	
72	84	0.27	118	P 2	TWD	10	VH3	-0.79	TEC	TEH		32	HOT	600UL	
		0.37	113	P 2	TWD	14	DBC	-2.00	TEC	TEH		32	HOT	600UL	
72	90	0.31	82	P 2	TWD	15	DBC	-1.61	TEC	TEH		36	HOT	600UL	
72	114	0.29	47	P 2	TWD	17	VC3	+0.83	TEC	TEH		28	HOT	600UL	
72	126	0.40	91	P 2	TWD	22	VSM	-0.77	TEC	TEH		17	HOT	600UL	
72	156	0.22	65	P 2	TWD	10	VC3	-0.83	TEH	TEC		28	COLD	600UL	
73	13	0.41	80	P 2	TWD	18	VH3	+0.90	TEH	TEC		54	COLD	600UL	
73	103	0.49	127	P 2	TWD	18	02H	-1.25	TEC	TEH		37	HOT	600UL	
73	105	1.05	63	P 2	TWD	29	VSM	-0.77	TEC	TEH		37	HOT	600UL	
		0.79	29	P 2	TWD	25	VH3	-0.43	TEC	TEH		37	HOT	600UL	
		1.62	113	P 2	TWD	37	VC3	-0.73	TEC	TEH		37	HOT	600UL	
74	44	0.68	136	P 2	TWD	25	VH3	-0.74	TEH	TEC		4	COLD	600UL	
74	54	0.20	150	P 2	TWD	9	DBH	-2.01	TEC	TEH		22	HOT	600UL	
74	56	0.31	81	P 2	TWD	14	DBH	+1.31	TEC	TEH		22	HOT	600UL	
74	72	0.32	86	P 1	SCI		TSH	+0.05	TSH	TSH	0.69	0.22	98	HOT	580PP
74	96	0.44	44	P 2	TWD	20	02H	-1.18	TEC	TEH		36	HOT	600UL	
74	132	0.27	99	P 2	TWD	11	VC3	-0.90	TEH	TEC		37	COLD	600UL	
74	148	0.37	149	P 2	TWD	14	VH3	-0.85	TEH	TEC		30	COLD	600UL	
		0.36	59	P 2	TWD	13	VSM	-0.85	TEH	TEC		30	COLD	600UL	
74	156	0.57	128	P 2	TWD	23	VH3	-0.92	TEH	TEC		29	COLD	600UL	
		0.57	103	P 2	TWD	23	VSM	-0.86	TEH	TEC		29	COLD	600UL	
		0.61	67	P 2	TWD	24	VC3	-0.80	TEH	TEC		29	COLD	600UL	
74	160	0.54	135	P 2	TWD	21	VC3	-0.85	TEH	TEC		26	COLD	600UL	
		1.17	106	P 2	TWD	33	VH3	-0.81	TEH	TEC		26	COLD	600UL	
75	51	0.20	116	P 2	TWD	9	DBH	-1.93	TEC	TEH		20	HOT	600UL	
75	79	0.53	120	P 2	TWD	20	DBC	-1.81	TEC	TEH		33	HOT	600UL	
75	85	1.11	24	P 2	TWD	32	DBC	+1.62	TEC	TEH		33	HOT	600UL	
75	87	0.41	152	P 2	TWD	17	DBC	-1.93	TEC	TEH		33	HOT	600UL	
75	105	0.18	88	P 1	SCI		TSH	+0.09	TSH	TSH	0.17	0.11	103	HOT	580PP
		0.46	98	P 2	TWD	20	VSM	-0.20	TEC	TEH		36	HOT	600UL	
		0.48	124	P 2	TWD	21	VH3	-0.79	TEC	TEH		36	HOT	600UL	
75	111	0.62	124	P 2	TWD	22	VH3	+0.10	TEC	TEH		31	HOT	600UL	
		0.90	125	P 2	TWD	28	VC3	+1.02	TEC	TEH		31	HOT	600UL	
76	42	0.33	132	P 2	TWD	17	DBC	-1.55	TEH	TEC		3	COLD	600UL	
76	78	0.45	126	P 2	TWD	16	VC3	+0.91	TEC	TEH		32	HOT	600UL	
		0.21	159	P 2	TWD	8	VC3	-0.97	TEC	TEH		32	HOT	600UL	

SG89 - MAI, MCI, MMI, MVI, SAI, SCI, SVI, 0-100%TWD

QUERY: QueryM1

ROW	LINE	VOLTS	DEG	CHN	IND	%TW	LOCATION	EXT	EXT	UTIL	1 UTIL	2 CAL #	LEG	PROBE	
76	114	0.37	92	P 2	TWD	20	VH3	-0.66	TEH	TEH		28	HOT	600UL	
76	142	0.27	98	P 2	TWD	12	08C	-0.53	TEH	TEC		33	COLD	600UL	
77	27	0.30	98	P 2	TWD	14	DBC	-1.98	TEH	TEC		49	COLD	600UL	
77	43	0.35	154	P 2	TWD	15	VH3	+0.81	TEH	TEC		4	COLD	600UL	
77	113	0.27	97	P 2	TWD	11	VH3	-0.99	TEH	TEH		29	HOT	600UL	
77	137	0.65	85	P 2	TWD	26	VSM	-0.85	TEH	TEC		34	COLD	600UL	
77	139	0.35	137	P 2	TWD	18	VH3	-0.83	TEH	TEC		32	COLD	600UL	
	0.68	140	P 2	TWD	28	VC3	+0.87	TEH	TEC		32	COLD	600UL		
78	44	0.40	142	P 2	TWD	17	VSM	-0.83	TEH	TEC		4	COLD	600UL	
78	122	0.24	129	P 2	TWD	12	08H	+0.87	TEC	TEH		18	HOT	600UL	
78	130	0.32	67	P 2	TWD	13	VSM	-0.89	TEH	TEC		36	COLD	600UL	
78	150	0.59	55	P 2	TWD	22	VH3	-0.73	TEH	TEC		30	COLD	600UL	
79	43	0.33	61	P 2	TWD	17	VH3	-0.61	TEH	TEC		3	COLD	600UL	
79	121	0.68	101	P 2	TWD	30	VH3	-0.95	TEC	TEH		17	HOT	600UL	
80	86	0.43	57	P 2	TWD	16	01H	-1.07	TEC	TEH		32	HOT	600UL	
80	106	0.24	46	P 2	TWD	12	VH3	+0.89	TEC	TEH		40	HOT	600UL	
80	152	0.51	114	P 2	TWD	22	VSM	+0.85	TEH	TEC		31	COLD	600UL	
	0.77	130	P 2	TWD	28	VSM	-0.85	TEH	TEC		31	COLD	600UL		
	0.70	103	P 2	TWD	26	VC3	-0.87	TEH	TEC		31	COLD	600UL		
	0.76	102	P 2	TWD	28	VC3	+0.83	TEH	TEC		31	COLD	600UL		
81	43	0.81	121	P 2	TWD	28	VSM	-0.84	TEH	TEC		4	COLD	600UL	
	0.51	115	P 2	TWD	20	VC3	-0.58	TEH	TEC		4	COLD	600UL		
81	55	0.34	85	P 2	TWD	16	VH3	-0.80	TEC	TEH		21	HOT	600UL	
81	75	0.21	86	P 2	TWD	9	VC3	+0.79	TEC	TEH		32	HOT	600UL	
81	79	0.47	85	P 2	TWD	17	VH3	-0.91	TEC	TEH		32	HOT	600UL	
81	85	0.27	42	P 2	TWD	10	VH3	+0.78	TEC	TEH		32	HOT	600UL	
81	105	0.24	118	P 2	TWD	11	VSM	+0.93	TEC	TEH		40	HOT	600UL	
	0.41	89	P 2	TWD	18	VH3	+0.83	TEC	TEH		40	HOT	600UL		
81	135	0.37	101	P 2	TWD	18	VH3	+0.87	TEH	TEC		34	COLD	600UL	
82	28	0.37	135	P 2	TWD	16	VH3	-0.72	TEH	TEC		49	COLD	600UL	
82	68	0.82	114	P 2	TWD	27	VH3	-0.84	TEC	TEH		10	HOT	600UL	
	0.39	147	P 2	TWD	16	VH3	+0.78	TEC	TEH		10	HOT	600UL		
82	148	0.81	118	P 2	TWD	29	VH3	-0.81	TEH	TEC		31	COLD	600UL	
84	96	0.60	22	P 1	SCI		TSH	-0.12	TSH	TSH	0.35	0.21	103	HOT	580PP
85	93	0.49	23	P 1	SCI		TSH	-0.09	TSH	TSH	0.00	0.19	107	HOT	580PP
85	99	0.53	32	P 2	TWD	19	02H	-1.24	TEC	TEH		37	HOT	600UL	
85	119	0.38	24	P 1	SCI		TSH	-0.05	TSH	TSH	0.20	0.22	64	HOT	600PP
85	123	0.34	13	P 1	SCI		TSH	-0.14	TSH	TSH	0.55	0.26	69	HOT	600PP
86	82	0.67	24	P 1	MCI		TSH	-0.12	TSH	TSH	0.98	0.16	98	HOT	580PP
88	36	0.40	77	P 2	TWD	17	VH2	-0.74	TEH	TEC		47	COLD	600UL	
88	40	0.39	111	P 2	TWD	18	VH2	-0.79	TEH	TEC		3	COLD	600UL	

SG89 - MAI, MCI, MMI, MVI, SAI, SCI, SVI, 0-100%TWD

QUERY: QueryM1

ROW	LINE	VOLTS	DEG	CHN	IND	%TW	LOCATION	EXT	EXT	UTIL	1 UTIL	2 CAL #	LEG	PROBE	
88	58	0.41	92	P 2	TWD	19	VH2	-0.90	TEC	TEH		21	HOT	600UL	
88	68	0.28	102	P 2	TWD	13	VH2	-1.00	TEC	TEH		9	HOT	600UL	
88	140	0.55	122	P 2	TWD	24	VH2	+1.14	TEH	TEC		32	COLD	600UL	
89	85	0.32	44	P 2	TWD	12	VH2	-0.89	TEC	TEH		32	HOT	600UL	
90	24	0.36	86	P 2	TWD	17	VH2	-1.00	TEH	TEC		17	COLD	600UL	
	0.38	26	P 2	TWD	18	VSM	-0.79	TEH	TEC		17	COLD	600UL		
90	34	0.29	158	P 2	TWD	15	VH2	-0.92	TEH	TEC		17	COLD	600UL	
90	52	.0.39	116	P 2	TWD	16	VH2	-0.99	TEC	TEH		1	HOT	600UL	
90	94	0.23	160	P 2	TWD	11	VSM	-0.78	TEH	TEC		10	COLD	600UL	
90	140	0.31	121	P 2	TWD	14	VH2	-0.81	TEH	TEC		25	COLD	600UL	
90	144	0.48	34	P 2	TWD	19	VSM	+0.89	TEH	TEC		25	COLD	600UL	
91	43	0.50	91	P 2	TWD	20	06C	-0.98	TEH	TEC		18	COLD	600UL	
91	145	0.32	116	P 2	TWD	14	VH2	-0.75	TEH	TEC		25	COLD	600UL	
91	151	0.39	52	P 2	TWD	17	VH2	-0.78	TEH	TEC		25	COLD	600UL	
93	23	1.08	90	P 2	TWD	34	02C	+0.87	TEH	TEC		17	COLD	600UL	
93	35	0.15	107	2	MAI	05H	+12.20	TO+20.90	05H	06H	0.00	8.70	156	HOT	580PP
	0.25	128	2	MAI	05H	+23.40	TO+33.80	05H	06H	0.00	10.40	156	HOT	580PP	
93	115	0.41	15	2	SAI	TSH	-0.36		TSH	TSH	0.46	0.46	88	HOT	600PP
94	26	0.46	102	P 2	TWD	19	VH2	+0.96	TEH	TEC		18	COLD	600UL	
94	50	0.25	105	P 2	TWD	11	05C	+0.00	TEC	TEH		2	HOT	600UL	
94	146	0.29	141	P 2	TWD	13	VH3	-0.87	TEH	TEC		25	COLD	600UL	
95	33	0.28	112	2	SAI	05H	+0.62		05H	05H	0.00	0.28	131	HOT	580PP
96	48	0.34	89	P 2	TWD	15	VH2	-0.85	TEC	TEH		1	HOT	600UL	
97	37	0.52	85	P 2	TWD	23	VC3	+0.92	TEH	TEC		17	COLD	600UL	
97	41	0.40	40	P 2	TWD	19	VH2	+0.92	TEH	TEC		17	COLD	600UL	
97	47	0.34	92	P 2	TWD	15	VH2	+0.75	TEC	TEH		1	HOT	600UL	
98	136	0.36	59	P 2	TWD	16	VH2	+0.82	TEH	TEC		23	COLD	600UL	
	0.29	88	P 2	TWD	14	VH2	-0.76	TEH	TEC		23	COLD	600UL		
100	26	0.36	103	P 2	TWD	17	VH2	+0.96	TEH	TEC		17	COLD	600UL	
100	46	0.25	146	P 1	MCI	TSH	+0.05		TSH	TSH	0.32	0.25	68	HOT	600PP
101	35	0.36	49	P 2	TWD	16	VH3	-0.69	TEH	TEC		18	COLD	600UL	
101	143	0.44	67	P 2	TWD	19	VH2	-0.77	TEH	TEC		23	COLD	600UL	
102	38	0.46	123	2	SAI	06H	-0.59		06H	06H	0.29	0.62	131	HOT	580PP
102	58	0.26	115	P 2	TWD	11	VC3	-0.73	TEC	TEH		44	HOT	600UL	
	0.29	155	P 2	TWD	11	VC2	-0.88	TEC	TEH		44	HOT	600UL		
	0.22	55	P 2	TWD	10	VC3	-0.92	TSC	TEH		6	HOT	600UL		
102	122	0.36	87	P 2	TWD	20	VC2	-0.80	TEC	TEH		7	HOT	600UL	
102	132	0.40	81	P 2	TWD	18	VH2	-0.79	TEH	TEC		23	COLD	600UL	
103	47	0.39	22	P 2	TWD	16	VH2	-0.91	TEC	TEH		2	HOT	600UL	
103	137	0.46	108	P 2	TWD	20	VH3	-0.79	TEH	TEC		23	COLD	600UL	

SG89 - MAI, MCI, MMI, MVI, SAI, SCI, SVI, 0-100%TWD

QUERY: QueryM1

ROW	LINE	VOLTS	DEG	CHN	IND	%TW	LOCATION	EXT	EXT	UTIL	1 UTIL	2	CAL #	LEG	PROBE	
104	94	0.60	147	P 2	TWD	24	VSM	-0.78	TEH	TEC		9	COLD	600UL		
106	40	0.18	112	2	MAI		06H	+3.14	TO+10.28	06H	06H	0.32	7.14	131	HOT	580PP
106	62	0.36	94	P 2	TWD	14	VC2	-0.88	TEC	TEH		6	HOT	600UL		
106	84	0.29	125	P 2	TWD	13	VH3	+0.87	TEH	TEC		10	COLD	600UL		
106	104	0.32	74	P 2	TWD	15	VC2	-0.75	TEH	TEC		46	COLD	600UL		
106	136	0.41	118	P 2	TWD	18	VH2	-0.75	TEH	TEC		23	COLD	600UL		
107	35	0.32	82	P 2	TWD	16	DBC	+1.81	TEH	TEC		17	COLD	600UL		
107	103	0.49	38	P 2	TWD	21	VH2	-0.92	TEH	TEC		11	COLD	600UL		
108	42	0.68	113	P 2	TWD	27	DBH	-1.85	TEH	TEC		17	COLD	600UL		
		0.35	95	P 2	TWD	17	DBH	+2.00	TEH	TEC		17	COLD	600UL		
109	47	0.32	111	P 2	TWD	15	VC3	-0.94	TEC	TEH		1	HOT	600UL		
		0.37	122	P 2	TWD	16	VSM	-1.00	TEC	TEH		1	HOT	600UL		
109	55	0.28	83	P 2	TWD	13	VH2	-0.82	TEC	TEH		1	HOT	600UL		
109	95	0.24	105	P 2	TWD	11	VSM	+0.46	TEH	TEC		10	COLD	600UL		
110	34	0.27	162	P 2	TWD	12	VH2	+0.94	TEH	TEC		18	COLD	600UL		
110	36	0.10	81	2	SAI		07H	-11.50	07H	07H	0.13	0.62	131	HOT	580PP	
111	43	0.57	51	P 2	TWD	22	VH3	-1.02	TEH	TEC		18	COLD	600UL		
111	99	0.41	44	P 2	TWD	18	09C	+0.47	TEH	TEC		10	COLD	600UL		
111	137	0.42	97	P 2	TWD	18	VH2	-0.77	TEH	TEC		23	COLD	600UL		
		0.35	91	P 2	TWD	16	VH2	+0.87	TEH	TEC		23	COLD	600UL		
112	72	0.36	64	P 2	TWD	17	VH3	+0.80	TEH	TEC		5	COLD	600UL		
112	128	0.22	99	P 2	TWD	13	VH2	+0.08	TEC	TEH		7	HOT	600UL		
112	144	0.55	60	P 2	TWD	22	DBC	+2.01	TEH	TEC		23	COLD	600UL		
113	105	0.39	93	P 2	TWD	16	VH2	+0.87	TEH	TEC		12	COLD	600UL		
		0.38	56	P 2	TWD	16	VC3	+0.91	TEH	TEC		12	COLD	600UL		
114	36	0.26	34	P 2	TWD	13	DBC	-1.77	TEH	TEC		17	COLD	600UL		
114	40	0.53	80	P 2	TWD	23	DBH	+2.13	TEH	TEC		17	COLD	600UL		
114	46	0.19	109	2	SAI		07H	-0.44	07H	07H	0.21	0.30	131	HOT	580PP	
114	62	0.31	137	P 2	TWD	12	DBH	-1.75	TEC	TEH		6	HOT	600UL		
114	76	0.24	135	P 1	SCI		TSH	+0.02	TSH	TSH	0.30	0.48	100	HOT	600PP	
114	136	0.34	146	P 2	TWD	16	VC3	+0.85	TEH	TEC		23	COLD	600UL		
117	95	0.42	123	P 2	TWD	19	DBC	+0.80	TEH	TEC		9	COLD	600UL		
118	70	0.41	98	P 2	TWD	17	VH1	-0.83	TEC	TEH		5	HOT	600UL		
118	84	0.38	66	P 2	TWD	16	VC2	+0.53	TEH	TEC		10	COLD	600UL		
118	128	0.28	112	P 2	TWD	12	05H	+0.67	TEC	TEH		8	HOT	600UL		
119	79	0.53	123	P 2	TWD	22	VH3	+0.86	TEH	TEC		7	COLD	600UL		
119	119	0.49	50	P 2	TWD	24	10H	-1.01	TEC	TEH	LOCOK	3	HOT	600UL		
119	121	0.50	120	P 2	TWD	26	10H	-1.09	TEC	TEH	LOCOK	7	HOT	600UL		
120	42	0.45	114	P 2	TWD	20	VH1	-0.81	TEH	TEC		17	COLD	600UL		

SG89 - MAI, MCI, MMI, MVI, SAI, SCI, SVI, 0-100%TWD

QUERY: QueryM1

ROW	LINE	VOLTS	DEG	CHN	IND	%TW	LOCATION	EXT	EXT	UTIL	1	UTIL	2	CAL	#	LEG	PROBE
120	60	0.46	140	P 2	TWD 19	VH1	-0.98	TEC	TEH				5	HOT		600UL	
120	62	0.26	152	P 2	TWD 12	VH1	-0.96	TEC	TEH				5	HOT		600UL	
120	68	0.39	101	P 2	TWD 16	VH1	-0.96	TEC	TEH				5	HOT		600UL	
120	72	0.43	144	P 2	TWD 17	10H	-1.20	TEH	TEC				6	COLD		600UL	
120	74	0.68	112	P 2	TWD 26	10H	-1.41	TEH	TEC	LAR			7	COLD		600UL	
120	128	0.12	89	2	SAI	02H	-14.73	02H	02H	0.49	0.33	137	HOT		580PP		
		0.35	82	P 2	TWD 20	08H	+0.79	TEC	TEH				7	HOT		600UL	
		0.37	120	P 2	TWD 21	VH1	-1.00	TEC	TEH				7	HOT		600UL	
121	39	0.33	76	P 2	TWD 16	10H	-1.82	TEH	TEC	LOCOK			17	COLD		600UL	
121	45	0.74	120	P 2	TWD 28	VC2	-0.53	TEH	TEC	LAR			17	COLD		600UL	
121	47	0.34	125	P 2	TWD 15	10H	+0.74	TEC	TEH				1	HOT		600UL	
121	77	0.17	114	2	SAI	03H	+0.38	03H	03H	0.17	0.47	121	HOT		580PP		
121	83	0.53	129	P 2	TWD 22	VC3	-0.82	TEH	TEC				8	COLD		600UL	
121	109	0.57	82	P 2	TWD 26	10H	-2.03	TEC	TEH	LOCOK			3	HOT		600UL	
122	40	0.24	16	P 2	TWD 12	02C	-0.17	TEH	TEC				17	COLD		600UL	
122	42	0.57	97	P 2	TWD 22	DBC	-2.19	TEH	TEC				18	COLD		600UL	
123	121	0.30	64	P 2	TWD 17	VH1	-0.98	TEC	TEH				7	HOT		600UL	
124	48	0.55	103	P 2	TWD 22	VH1	-0.96	TEC	TEH				1	HOT		600UL	
124	56	0.50	69	P 2	TWD 19	VH1	-0.98	TEC	TEH				6	HOT		600UL	
125	53	0.37	138	P 2	TWD 16	VH1	-0.96	TEC	TEH				1	HOT		600UL	
125	77	0.34	135	P 2	TWD 16	VH1	+0.86	TEH	TEC				8	COLD		600UL	
		0.25	41	P 2	TWD 13	VH1	-0.81	TEH	TEC				8	COLD		600UL	
126	48	0.40	111	P 2	TWD 16	VH1	-1.19	TEC	TEH				2	HOT		600UL	
126	50	0.28	112	P 2	TWD 13	VH1	-1.12	TEC	TEH				1	HOT		600UL	
126	56	0.49	88	P 2	TWD 20	VH1	-1.08	TEC	TEH				5	HOT		600UL	
126	126	0.36	91	P 2	TWD 15	VH1	-1.24	TEC	TEH				8	HOT		600UL	
127	123	0.31	140	P 2	TWD 18	09C	-1.18	TEC	TEH				7	HOT		600UL	
128	72	0.25	148	P 2	TWD 11	10H	-1.05	TEH	TEC				6	COLD		600UL	
		0.40	67	P 2	TWD 16	10H	+0.85	TEH	TEC				6	COLD		600UL	
129	47	0.41	146	P 2	TWD 18	10H	+0.74	TEC	TEH				1	HOT		600UL	
129	49	0.23	91	P 2	TWD 11	VH1	+0.86	TEC	TEH				1	HOT		600UL	
		0.35	79	P 2	TWD 16	VH1	-0.84	TEC	TEH				1	HOT		600UL	
129	73	0.22	47	P 2	TWD 11	DBH	+1.80	TEH	TEC				8	COLD		600UL	
129	109	0.23	134	P 2	TWD 14	10H	-0.94	TEC	TEH				3	HOT		600UL	
130	48	0.43	77	P 2	TWD 18	02C	-0.08	TEC	TEH				1	HOT		600UL	
130	52	0.36	137	P 2	TWD 16	VH1	-0.90	TEC	TEH				1	HOT		600UL	
130	54	0.45	128	P 2	TWD 18	VH1	-0.86	TEC	TEH				1	HOT		600UL	
130	74	0.34	130	P 2	TWD 16	10H	+0.92	TEH	TEC				8	COLD		600UL	
130	78	0.54	96	P 2	TWD 22	10H	-1.04	TEH	TEC				8	COLD		600UL	
130	110	0.36	152	P 2	TWD 15	VH1	-0.85	TEC	TEH				4	HOT		600UL	

SG89 - MAI, MCI, MMI, MVI, SAI, SCI, SVI, 0-100%TWD

QUERY: QueryM1

ROW	LINE	VOLTS	DEG	CHN	IND	%TW	LOCATION	EXT	EXT	UTIL	1 UTIL	2 CAL #	LEG	PROBE
130	116	0.46	74	P 2	TWD 19	VH1	-0.90	TEH	TEH		4	HOT	600UL	
132	106	0.29	87	P 2	TWD 13	10H	-1.18	TEH	TEC		15	COLD	600UL	
133	55	0.28	73	P 2	TWD 12	02H	+0.26	TEH	TEC	LAR	14	COLD	600UL	
133	81	0.55	108	P 2	TWD 20	VH1	+0.85	TEH	TEC		14	COLD	600UL	
133	85	0.40	108	P 2	TWD 16	06H	+0.83	TEH	TEC		14	COLD	600UL	
133	119	0.42	149	P 2	TWD 19	VH1	+0.91	TEH	TEC		20	COLD	600UL	
133	125	0.28	44	P 2	TWD 13	01C	+0.86	TEH	TEC		20	COLD	600UL	
134	52	0.34	92	P 2	TWD 14	VH1	-0.77	TEH	TEC		14	COLD	600UL	
134	64	0.39	130	P 2	TWD 16	VC3	-0.88	TEH	TEC		13	COLD	600UL	
	0.37	98	P 2	TWD 16	VH3	-0.92	TEH	TEC			13	COLD	600UL	
134	88	0.37	79	P 2	TWD 15	VH1	+0.84	TEH	TEC		14	COLD	600UL	
134	124	0.22	75	P 2	TWD 13	VC3	+0.62	01C	TEH		76	HOT	600UL	
136	68	0.52	60	P 2	TWD 21	VH1	-0.87	TEH	TEC		13	COLD	600UL	
136	88	0.41	81	P 2	TWD 18	06H	+0.60	TEH	TEC		13	COLD	600UL	
137	69	0.39	51	P 2	TWD 15	VH1	+0.59	TEH	TEC		14	COLD	600UL	
137	71	0.38	120	P 2	TWD 15	DBH	-1.77	TEH	TEC		14	COLD	600UL	
138	64	0.35	91	P 2	TWD 14	10H	+0.75	TEH	TEC		14	COLD	600UL	
138	76	0.46	148	P 2	TWD 18	VH1	-0.81	TEH	TEC		14	COLD	600UL	
138	92	0.54	77	P 2	TWD 20	07C	+1.19	TEH	TEC		14	COLD	600UL	
138	104	0.30	108	P 2	TWD 14	VH1	+0.84	TEH	TEC		15	COLD	600UL	
139	61	0.31	97	P 2	TWD 13	09C	-1.04	TEH	TEC		14	COLD	600UL	
139	103	0.56	145	P 2	TWD 23	VH2	+0.91	TEH	TEC		15	COLD	600UL	
140	100	0.27	145	P 2	TWD 11	VC1	+0.85	TEH	TEC		16	COLD	600UL	
141	67	0.37	93	P 2	TWD 15	09C	-1.08	TEH	TEC		14	COLD	600UL	
141	103	0.38	126	P 2	TWD 16	VH3	-0.93	TEH	TEC		16	COLD	600UL	
141	109	0.53	89	P 2	TWD 22	VH3	-0.02	TEH	TEC		15	COLD	600UL	
142	92	0.47	116	P 2	TWD 18	VH1	-0.89	TEH	TEC		14	COLD	600UL	
143	71	0.57	108	P 2	TWD 21	VH1	-0.90	TEH	TEC		14	COLD	600UL	
	0.45	93	P 2	TWD 17	VH1	+0.75	TEH	TEC			14	COLD	600UL	
	0.48	65	P 2	TWD 18	DBH	+2.04	TEH	TEC			14	COLD	600UL	
143	73	0.24	134	P 2	TWD 10	DBC	+1.81	TEH	TEC		14	COLD	600UL	
	0.42	121	P 2	TWD 16	DBC	-1.81	TEH	TEC			14	COLD	600UL	
143	81	0.29	17	P 2	TWD 12	VC1	-0.83	TEH	TEC		14	COLD	600UL	
143	87	0.29	128	P 2	TWD 13	10C	+0.85	TEH	TEC		13	COLD	600UL	
	0.54	74	P 2	TWD 22	DBC	+1.66	TEH	TEC			13	COLD	600UL	
143	103	0.57	109	P 2	TWD 23	DBH	+1.58	TEH	TEC		15	COLD	600UL	
143	109	0.75	76	P 2	TWD 26	DBC	-1.77	TEH	TEC		16	COLD	600UL	
144	74	0.86	119	P 2	TWD 28	VC1	+0.94	TEH	TEC		14	COLD	600UL	
	0.28	103	P 2	TWD 12	DBC	-1.77	TEH	TEC			14	COLD	600UL	
144	102	0.29	115	P 2	TWD 12	DBH	-1.69	TEH	TEC		16	COLD	600UL	
145	75	0.56	118	P 2	TWD 21	DBH	+1.99	TEH	TEC		14	COLD	600UL	

SG89 - MAI, MCI, MMI, MVI, SAI, SCI, SVI, 0-100%TWD

QUERY: QueryM1

ROW	LINE	VOLTS	DEG	CHN	IND	%TW	LOCATION	EXT	EXT	UTIL	1 UTIL	2	CAL #	LEG	PROBE
---	---	---	---	---	---	---	---	---	---	---	---	---	---	---	---
145	81	0.84	93	P	2	TWD	29	VH1	+0.81	TEH	TEC	13	COLD	600UL	
145	89	0.46	88	P	2	TWD	19	VC2	+0.88	TEH	TEC	13	COLD	600UL	
145	91	1.14	97	P	2	TWD	33	DBC	+1.77	TEH	TEC	14	COLD	600UL	
145	103	0.90	110	P	2	TWD	29	DBH	+1.81	TEH	TEC	16	COLD	600UL	
146	78	0.46	81	P	2	TWD	18	DBH	+1.90	TEH	TEC	14	COLD	600UL	
146	88	0.70	46	P	2	TWD	24	DBC	+1.65	TEH	TEC	14	COLD	600UL	
146	92	0.94	116	P	2	TWD	29	DBC	+1.79	TEH	TEC	14	COLD	600UL	
		.0.29	128	P	2	TWD	13	DBH	+1.87	TEH	TEC	14	COLD	600UL	
146	94	0.93	60	P	2	TWD	29	DBC	+1.76	TEH	TEC	14	COLD	600UL	
		0.44	99	P	2	TWD	17	DBH	+1.98	TEH	TEC	14	COLD	600UL	
146	98	0.44	55	P	2	TWD	18	03H	-1.17	TEH	TEC	16	COLD	600UL	
147	81	1.26	80	P	2	TWD	34	DBC	+1.82	TEH	TEC	14	COLD	600UL	

Total Tubes : 417
Total Records: 506